

File No.EMC/91/2022-ETB-3(EED)




Energy Management Centre

(State Designated Agency to enforce Energy Conservation Act 2001)
Department of Power, Government of Kerala
Sreekrishna Nagar, Sreekariyam PO,
Thiruvananthapuram, 695 017
Tel: 0471-2594922, 2594924
E-mail: emck@keralapower.gov.in
Website: www.keralaenergy.gov.in

No: EMC/91/2022-ETB-3(EED)

1214
10/06/2022

The Principal
Sree Chitra Thirunal College of Engineering
Pappanamcode
Thiruvananthapuram
695018



EW/By Bobby
P. Sreekumar
6/9/22

Sir,

Sub: Energy Audit Report - Reg

Ref: 1. EMC letter No. EMC/91/2022-ETB-3(EED) dated 08/04/2022

Energy Management Centre - Kerala (EMC), Department of Power, Government of Kerala is the State Designated Agency to coordinate, enforce and implement Energy Conservation Act - 2001 (Central act 52 of 2002) in Kerala. As part of the Solar City Project, we conducted an energy audit at Sree Chitra Thirunal College of Engineering.

We are enclosing herewith the final report of the energy audit conducted at "Sree Chitra Thirunal College of Engineering". We would appreciate if you could send us your action plan for the implementation of various energy efficiency and energy conservation measures. Also, request you to forward the acceptance of the report. Please note that, if the acceptance is not received within 15 days from the receipt of this letter, it may be treated as the final energy audit report is accepted.

Please feel free to contact us for any further clarifications.

Thanking you,


Yours faithfully,

Director


Enc: En



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18



ENERGY AUDIT REPORT
SREE CHITRA THIRUNAL COLLEGE OF ENGINEERING
THIRUVANANTHAPURAM, KERALA
FEBRUARY 2022



Energy Management Centre – Kerala
Dept of Power, Govt of Kerala.
State Designated Agency
Sreekrishna Nagar, Sreekariyam P.O.,
Thiruvananthapuram – 695 017
Ph: 0471 - 2594922, 2594924
Fax: 0471 – 2594923
email: emck@keralaenergy.gov.in




PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

ENERGY AUDIT AT

SREE CHITRA THIRUNAL COLLEGE OF ENGINEERING
THIRUVANANTHAPURAM, KERALA

Conducted By



ENERGY MANAGEMENT CENTRE – KERALA

Dept. of Power, Govt. of Kerala, State Designated Agency
Sreekrishna Nagar, Sreekariyam P.O.,
Thiruvananthapuram – 695 017
Ph: 0471 - 2594922, 2594924, Fax: 0471 – 2594923
Email: emck@keralaenergy.gov.in

Prepared by



Indira Babu Energy Ventures Pvt Ltd.
Thiruvathira, CP III 520
Kottamughal, Nalanchira P O
Thiruvananthapuram, Kerala- 695015



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Thiruvananthapuram - 695 015

CERTIFICATION

This is to certify that

The data collection has been carried out diligently and truthfully; All data monitoring devices are in good working condition and have been calibrated or certified by approved agencies authorised and no tampering of such devices has occurred; All reasonable professional skill, care and diligence had been taken in preparing the energy audit report and the contents thereof are a true representation of the facts; Adequate training provided to personnel involved in daily operations after implementation of recommendations.

Jishnu Sanath
Certified Energy Auditor



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

TABLE OF CONTENTS

| | |
|---|----|
| 1. ACKNOWLEDGEMENT..... | 2 |
| 2. CERTIFICATION..... | 3 |
| 3. EXECUTIVE SUMMARY..... | 4 |
| 4. INTRODUCTION..... | 7 |
| 5. ENERGY & UTILITY DESCRIPTION | 11 |
| 1. BASELINE DATA & CONSUMPTION: 12 MONTHS..... | 11 |
| 2. Demand ANALYSIS | 12 |
| 3. POWER FACTOR ANALYSIS IN ENERGY BILL | 14 |
| 6. ENERGY PERFORMANCE | 16 |
| 7. ENERGY PERFORMANCE ASSESSMENT OF MAJOR EQUIPMENTS..... | 18 |
| I. ELECTRICAL SYSTEM..... | 20 |
| II. DIESEL GENERATOR..... | 20 |
| III. HVAC & VENTILATION..... | 20 |
| IV. LIGHTING SYSTEM | 20 |
| 8. POWER QUALITY ASSESSMENT..... | 32 |
| 9. THERMOGRAPHY REPORT | 39 |
| 10. RECOMMENDATIONS IN DETAIL FOR ENERGY CONSERVATION | 42 |
| 11. CLIMATE IMPACT | 58 |
| 12. ENERGY POLICY | 59 |
| 13. RENEWABLE ENERGY INTEGRATION..... | 60 |
| 14. ANNEXURE 1: List of Instruments..... | 61 |
| 15. ANNEXURE 2: Lux Level Table | 62 |
| 16. ANNEXURE 3: List Of Appliances | 63 |
| 17. ANNEXURE 4: List Of Lab Equipments | 63 |
| 18. ANNEXURE 5: List Of Buildings..... | 66 |
| 19. ANNEXURE 6: List Of Manufacturers | 66 |
| 20. ANNEXURE 7: Room Wise List of Equipments | 66 |



1. ACKNOWLEDGEMENT

We express our sincere gratitude to the management of **Sree Chitra Thirunal College of Engineering, Thiruvananthapuram** for granting us an opportunity to carry out the project of Energy Audit. We thank **Energy Management Centre Kerala** for entrusting us the work of detailed Energy Audit at **Sree Chitra Thirunal College of Engineering, Thiruvananthapuram. (SCTCE)**

SCTCE Team

- Mr. Dr. V. Syam Prakash, Principal, SCT College of Engineering
- Mr. Dr. Bobby Philip, HOD Electrical Division

Our Energy Audit team

- Mr. Jishnu Sanath – Certified Energy Auditor (BEE, Govt of India)
- Dr. Vani Vijay, Technology & Research expert
- Er. Anoop Babu, Energy Consultant
- Er. Kokila Vijayakumar, Operations Head
- Er. Akhil Dev. D.J, Energy & Market Analyst
- Er. Shabinsha, Electrical Specialist
- Er. Sruthy. A.A, Engineer

Director
Energy Management Centre

Thiruvananthapuram
26-02-2022



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Thiruvananthapuram - 18

3. EXECUTIVE SUMMARY

The **Vydyuthi Energy Services (VES)** conducted a Detailed Energy Audit at Sree Chitra Thirunal College Thiruvananthapuram, bearing Consumer number-1345120045141 during February 2022, as per the work order issued by **Energy management Centre-Kerala**.

There is an energy saving potential of about **51739 kWh** per year at an investment of Rs **2443783** summarised as below. About 21.78% energy saving potential is assessed with an annual financial savings of about Rs. **597256** and a simple payback period of **4.09 years** to recover the investment.

| Sl. No | Area | Description of Work | No. of Equipment | Annual Energy Saving Potential (kWh) | Annual Financial Savings (Rs.) | Investment Required (Rs.) | Payback Period-Years |
|--------|-----------------------|--|------------------|--------------------------------------|--------------------------------|---------------------------|----------------------|
| 1 | | Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light. | 226 | 8846 | 88280 | 90400 | 1 |
| 2 | | Retrofitting of 2x52W (2xT12) ordinary tube light with 2x18W LED tube light. | 88 | 9078 | 90598 | 70400 | 1 |
| 3 | | Retrofitting of 36W (T8) ordinary tube light with 18W LED tube light. | 1 | 32 | 314 | 400 | 1 |
| 4 | College Main Building | Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan | 371 | 13126 | 130995 | 1113000 | 8 |
| 5 | | Retrofitting of existing ordinary and old air conditioner (1.5T) with inverter air conditioner/BEE star rated air conditioner. | 4 | 2592 | 25868 | 132000 | 5 |
| 6 | | Retrofitting of existing ordinary and old air conditioner (1T) with inverter air conditioner/BEE star rated air conditioner. | 6 | 2057 | 20524 | 180000 | 6 |
| 7 | Main lab building | Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light. | 124 | 1314 | 13117 | 49600 | 4 |



(Handwritten signature)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| | | | | | | | |
|----|----------------------|--|-----|------|-------|--------|---|
| 8 | | Retrofitting of 2x52W (2xT12) ordinary tube light with 2x18W LED tube light. | 94 | 2298 | 22936 | 75200 | 3 |
| 9 | | Retrofitting of 36W (T8) ordinary tube light with 18W LED tube light. | 8 | 72 | 719 | 3200 | 4 |
| 10 | | Retrofitting of 14W CFL bulb with 7W LED bulb. | 6 | 135 | 1347 | 4200 | 3 |
| 11 | | Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan | 102 | 4144 | 41355 | 306000 | 7 |
| 12 | | Retrofitting of existing ordinary and old air conditioner (1.5T) with inverter air conditioner/BEE star rated air conditioner. | 1 | 648 | 6467 | 33000 | 5 |
| 13 | | Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light. | 37 | 710 | 7089 | 14800 | 2 |
| 14 | Canteen building | Retrofitting of 2x52W (2xT12) ordinary tube light with 2x18W LED tube light. | 44 | 1984 | 19805 | 35200 | 2 |
| 15 | | Retrofitting of 14W CFL bulb with 7W LED bulb. | 4 | 15 | 146 | 480 | 3 |
| 16 | | Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan | 50 | 1875 | 18713 | 150000 | 8 |
| 17 | | Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light. | 14 | 357 | 3563 | 5600 | 2 |
| 18 | Post office building | Retrofitting of 36W (T8) ordinary tube light with 18W LED tube light. | 3 | 41 | 404 | 1200 | 3 |
| 19 | | Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan | 16 | 600 | 5988 | 48000 | 8 |
| 20 | LAB building 2 | Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light. | 9 | 102 | 1018 | 3600 | 4 |



(Handwritten signature)

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| | | | | | | | |
|--------------|--|--|----|--------------|---------------|----------------|-------------|
| 21 | | Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan | 10 | 375 | 3743 | 30000 | 8 |
| 22 | | Retrofitting of existing ordinary and old air conditioner (2T) with inverter air conditioner/BEE star rated air conditioner. | 1 | 686 | 6841 | 42000 | 6 |
| 23 | CGPU Office | Retrofitting of 14W CFL bulb with 7W LED bulb. | 1 | 4 | 35 | 120 | 3 |
| 24 | | Retrofitting of existing ordinary and old air conditioner (1.5T) with inverter air conditioner/BEE star rated air conditioner. | 1 | 648 | 6467 | 33000 | 5 |
| 25 | Power factor optimization from 0.87 to 1 | | | | 80924 | 22383 | 4 |
| TOTAL | | | | 51739 | 597256 | 2443783 | 4.09 |

Renewable Energy Potential

| Sl. No | Description of Work | Annual Energy Generation (kWh) | Annual Equivalent Cost of Energy Generated (Rs.) | Investment Required (Rs.) | Payback Period-Years |
|--------------|--|--------------------------------|--|---------------------------|----------------------|
| 1 | Installation of 170kWp Roof Top Solar PV Power Plant as a part of renewable energy integration | 244800 | 1517760 | 11050000 | 7.28 |
| TOTAL | | 244800 | 1517760 | 11050000 | 7.28 |



(Handwritten signature in green ink)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

4. INTRODUCTION

ENERGY MANAGEMENT CENTRE (EMC) - KERALA

Energy Management Centre (EMC) – Kerala under Department of Power, Government of Kerala, is working towards attaining energy efficiency in all sectors of economy. EMC is formulating and implementing energy conservation projects and programs. In compliance with the Energy Conservation Act - 2001, Government of Kerala has designated EMC as the State Designated Agency (SDA) to enforce, regulate and co-ordinate the activities of Energy Conservation Act. Bureau of Energy Efficiency (BEE), Ministry of Power, Government of India is the coordinating agency to implement the Act in the country. EMC is working very closely with Bureau of Energy Efficiency, Government of India and all the stake holders in initiating and implementing energy efficiency measures in the State.

With intention to enhance the energy efficiency of the various sectors of the economy EMC have envisaged various programs. To enhance energy conservation and energy efficiency of Low tension (LT) consumers a preliminary LT energy audit has been designed as a walk through energy audit.

Energy Management Centre (EMC) – Kerala has entrusted M/s. Indira Babu Energy Ventures Pvt. Ltd. the work of conducting energy audit at Sree Chitra Thirunal College of Engineering

Major Activities of EMC

1. Monitoring and Verification of Energy Data of Designated Consumers and their PAT Scheme.
2. Mandatory Energy Audit for HT & EHT Consumers
3. Energy Efficiency training programme at Industrial Clusters/Parks/Estates
4. Energy Conservation Building Code (ECBC)
5. Energy Efficient Street Lighting
6. Municipal Demand Side Management (MuDSM)
7. Agriculture Demand Side Management (AgDSM).
8. Go-Electric Campaign
9. Urjayan Scheme for Legislative Assembly constituencies.
10. Energy Meter Calibration & LED Testing Lab
11. Kerala State Energy Conservation Award
12. Smart Energy Program for Students
13. Energy Efficiency Capacity Building Program
14. Urjakiran - Awareness programs for general public
15. Energy Clinic
16. Research & Studies



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

BASIC DETAILS OF THE BUILDING

Sree Chitra Thirunal College of Engineering (SCTCE), Thiruvananthapuram was established by the Govt. of Kerala in the year 1995 in memoriam of the Great Maharaja of Travancore and is affiliated to the APJ Abdul Kalam Technological University (KTU) of Kerala with AICTE approval. The Institution has the broad objective of grooming young men and women into technocrats through the process of engineering education, training and research. SCTCE offers 9 undergraduate and 3 postgraduate courses. SCTCE is also a research centre under APJ Abdul Kalam Technological University since 2015 and offers PhD programmes under the Departments of Mechanical Engineering, Electronics and Communication and Computer Science and Engineering. The accreditation of its courses by National Board of Accreditation (NBA) is a testimony to the quality of teaching learning process in the institute. The faculty members of the institute are highly experienced and most holding PhD degrees, thereby enhancing their ability to guide students to innovation and research.

The Institute also encourages students to develop their organizational, team building, presentation and other soft skills through a host of activities promoted through chapters of IEEE, ASME, CSI, SAE, EDC, NSS, KBAIC etc. SCTCE also maintains MoUs with industry and research organizations providing opportunities for students to work on real time projects. The placement statistics of the institute is one of a kind and speaks volumes about the students that graduate from the institute. A fairly large number of students also pursue higher education in premier institutes in India and abroad. SCTCE also had the privilege of being one of the top seven colleges in Kerala, aided under the World Bank funded Technical Education Quality Improvement Program (TEQIP) – phase I of the Govt of India.



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

1. GENERAL INFORMATION

Basic details – Sree Chitra Thirunal College of Engineering, Thiruvananthapuram

| Sl.No. | Items | Details |
|--------|--|---|
| 1 | Name of the Building | Sree Chitra Thirunal College of Engineering, Thiruvananthapuram |
| 2 | Category/Type of Building (Govt Office, Hospital, LSGD etc) | Engineering College |
| 3 | Name of the Assembly Constituency with District | Thiruvananthapuram |
| 4 | Address with phone number and e-mail ID | NH 66, CTO Colony, Pappanamcode, Thiruvananthapuram, Kerala 695018, 0471-2490572, principal@sctce.ac.in |
| 5 | Name of the Contact Person with Contact details | Mr. Boby Philip 9495741482 |
| 6 | Detailed energy audit last Conducted (Year) | Nil |
| 7 | Name of the audit Firm | Nil |
| 8 | Number of Government offices/Departments | 4 |
| 9 | Number of Staff (Permanent) | 122 |
| 10 | Number of students | 2200 |
| 11 | No of Working Hours/day | 7hr/day |
| 12 | No of Working days/Year | 250 |
| 13 | Staff Canteen/ Restaurant | yes |
| 14 | Scope for renewable energy integration | Yes |
| 15 | Roof type (Concrete, MP Tiles etc) | Concrete/AC sheets |
| 16 | Roof - shape (Flat/ Sloping roof) | Flat, Sloping roof |
| 17 | Roof Area (Sq. M) | 7828.2 |
| 18 | Reflective coating on roof (Y/N) | No |
| 19 | Type of Glazing used in windows (Single Glazed / Double Glazed Window) | Single glazed |
| 20 | Whether UPS is placed inside an air conditioned room? (Y/N) | No |
| 21 | Is false ceiling provided in air conditioned area? (Y/N) | Yes |
| 22 | Automatic Lighting Controls | No |



Energy Details –Sree Chitra Thirunal College of Engineering, Thiruvananthapuram

| Sl.no | Items | 2020 - 21 | 2021 - 22 |
|-------|---|---|-----------|
| 1 | Name of the Building | Sree Chitra Thirunal College of Engineering, Thiruvananthapuram | |
| 2 | KSEBL Consumer No: | 1345120045141 | |
| 3 | KSEBL Section Office: | Karamana | |
| 4 | Connected Load (kW) | 629.35 | |
| 5 | Contract Demand (kVA) | 200 | |
| 6 | Recorded Average Maximum Demand (kVA) | 76.9 | 52.33 |
| 7 | Total Transformer capacity (kVA) | 500 | |
| 8 | Average Power Factor | 0.90 | 0.88 |
| 9 | Air conditioned area (Sq. M) | 2400m ² | |
| a. | Less than 50% | Yes | |
| b. | More than 50% | | |
| 10 | Annual electricity consumption of the building (kWh) | 1661942 | 1565469 |
| 11 | Total built up area of the Building (Sq.m) | 18985.4 | |
| 12 | Specific Energy Consumption (KWh/ Sq.m) | 12.65 kWh/sqm/year | |
| 13 | Water Source (Open well /KWA) | KWA | |
| 14 | Water Consumption per Year (kL) | NA | 3000 |
| 15 | Annual Water bill (KWA). Rs. | NA | 90000 |
| 16 | Number of vehicles - 4 Wheeler (Own) | NA | 3 |
| 17 | Number of vehicles – bus | | 3 |
| 18 | Number of vehicles (2 Wheeler) | Nil | Nil |
| 19 | Total Diesel/ Petrol consumption of the vehicles (Litres) | NA | 6350 |
| 20 | Number of electric vehicles (if any) | Nil | Nil |
| 21 | Renewable Energy (Solar PV - kWp) | Nil | Nil |
| 22 | Renewable Energy (Bio gas plant - Cub. M) | Nil | Nil |
| 23 | Present status of the RE system (Working or Not) if any | Nil | |
| 24 | Own Diesel Generator (kVA) | 125 kVA | |
| 25 | Annual Diesel Consumption for DG (Litres) | 200litres | |



PRINCIPAL

Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

5. ENERGY & UTILITY DESCRIPTION

1. BASELINE DATA & CONSUMPTION: 12 MONTHS

The Electricity baseline data, based on the energy bills is summarized in the table below:


Table 1: BASE LINE DATA - (Based on Feb 2021- Jan 2022)

| SL NO | Particulars | Data |
|-------|--|----------------|
| 1 | Electricity provider | KSEBL |
| 2 | Supply voltage | 11KV |
| 3 | Tariff | HT2(B) GENERAL |
| 4 | Consumer number | 1345120045141 |
| 5 | Substation | Thirumala 33kV |
| 6 | Contract demand (kVA) | 200 |
| 7 | Maximum demand registered (kVA) | 71.27 |
| 8 | Average monthly electricity consumption (kWh) | 10677.25 |
| 9 | Average demand charges (Rs/month) | 23025 |
| 10 | Average power factor | 0.88 Lagging |
| 11 | Monthly Average power factor incentives (Rs) | 93.32 |
| 12 | Monthly Average power factor penalties (Rs) | 2526.6 |
| 13 | Average Tariff rate for energy consumption (Rs/kWh) | Normal-6.2 |
| | | Peak-9.3 |
| | | Off peak-4.65 |
| | | Average - 6.72 |
| 14 | Demand charges (Rs/kVA) | 440 |
| 15 | Average Monthly electricity cost (Rs) | 130455.75 |
| 16 | Average cost for electricity per unit = Annual energy bill amount/Annual units consumed (For the year 2019 considering normal operation before pandemic) | 9.98 |

INFERENCE

- Reference maximum demand (RMD) during the past financial year was 71.27kVA, which is 35.6 % of the contract demand.
- Power factor was in the range of 0.88 lagging during the last financial year which resulted in a penalty of Rs. 30319.28.




 PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18


2. DEMAND ANALYSIS

The trend of Maximum Demand versus Contract Demand (CD) is analyzed over the past financial year below:

Table 2: Maximum Demand vs Contract Demand

| Particulars | Feb-21 | Mar-21 | Apr-21 | May-21 | Jun-21 | Jul-21 | Aug-21 | Sep-21 | Oct-21 | Nov-21 | Dec-21 | Jan-22 |
|-------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Recorded Maximum demand (kVA) | 40.5 | 46.5 | 52.88 | 55.69 | 53.72 | 52.71 | 51.27 | 49.45 | 47.89 | 48.24 | 58.4 | 71.27 |
| Contract Demand(kVA) | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 |
| 75% of Contract demand (kVA) | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 | 150 |

Maximum Demand Trend



INFERENCE

1. Recorded maximum demand is less than 75% of contract demand every month.



(Handwritten Signature)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandram - 78

SUGGESTION

1. Contract demand reduction can reduce the overall energy bill amount considering the overall post pandemic load and future expansion. A proposal has been created for reducing the contract demand from 200 to 150 kVA and corresponding unutilized demand charges and prospect for financial savings has been demonstrated in the following table.

| Month | Present demand | Unutilized demand charges paid | 75% of present Contract demand | 75% Proposed contract demand | Savings in demand charges | Reduction in unutilized demand charges |
|--------|----------------|--------------------------------|--------------------------------|------------------------------|---------------------------|--|
| Feb-21 | 40.5 | 48180 | 150 | 112.5 | 16500 | 31680 |
| Mar-21 | 46.5 | 45540 | 150 | 112.5 | 16500 | 29040 |
| Apr-21 | 52.88 | 42732.8 | 150 | 112.5 | 16500 | 26232.8 |
| May-21 | 55.69 | 41496.4 | 150 | 112.5 | 16500 | 24996.4 |
| Jun-21 | 53.72 | 42363.2 | 150 | 112.5 | 16500 | 25863.2 |
| Jul-21 | 52.71 | 42807.6 | 150 | 112.5 | 16500 | 26307.6 |
| Aug-21 | 51.27 | 43441.2 | 150 | 112.5 | 16500 | 26941.2 |
| Sep-21 | 49.45 | 44242 | 150 | 112.5 | 16500 | 27742 |
| Oct-21 | 47.89 | 44928.4 | 150 | 112.5 | 16500 | 28428.4 |
| Nov-21 | 48.24 | 44774.4 | 150 | 112.5 | 16500 | 28274.4 |
| Dec-21 | 58.4 | 40304 | 150 | 112.5 | 16500 | 23804 |
| Jan-22 | 71.27 | 34641.2 | 150 | 112.5 | 16500 | 18141.2 |
| | | 515451.2 | | | 198000 | 317451.2 |



[Handwritten signature in green ink]


PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

3. POWER FACTOR ANALYSIS IN ENERGY BILL

The power factor variation over the last financial year is given below:

Table 3: Power Factor vs Maximum Demand

| Particulars | Feb-21 | Mar-21 | Apr-21 | May-21 | Jun-21 | Jul-21 | Aug-21 | Sep-21 | Oct-21 | Nov-21 | Dec-21 | Jan-22 |
|----------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Power factor | 0.88 | 0.9 | 0.91 | 0.91 | 0.9 | 0.9 | 0.88 | 0.86 | 0.84 | 0.84 | 0.86 | 0.88 |
| Maximum demand | 40.54 | 46.5 | 52.88 | 55.69 | 53.12 | 52.71 | 51.27 | 49.45 | 47.89 | 48.24 | 58.4 | 71.27 |



INFERENCE

1. The average power factor is 0.88 during the last year.
2. Power factor is found to be lagging.

SUGGESTION

1. Replacement/Repair of the deteriorated capacitors in the APFC will improve the power factor and fetch incentives.



(Handwritten signature in green ink)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

ENERGY BILL DATA – FEB 2021 TO JAN 2022

Table 4: Energy Bill

| Month | Maximum Demand (kVA) | | | Energy (kWh) | | | | Avg MD (kVA) | PF | PF Incentives/penalties | Total Bill Amount (Rs) |
|--------|----------------------|-------|----------|--------------|------|----------|-------|--------------|-----|-------------------------|------------------------|
| | Normal | Peak | Off peak | Normal | Peak | Off peak | Total | | | | |
| Feb-21 | 57.77 | 14.54 | 14.67 | 8538 | 1185 | 2394 | 12117 | 40.54 | 0.9 | -375.44 | 14871.51 |
| Mar-21 | 64.97 | 15.07 | 14.36 | 8694 | 1125 | 2169 | 11988 | 46.5 | 0.9 | -744.51 | 147451.5 |
| Apr-21 | 74.72 | 15.62 | 13.87 | 10197 | 1245 | 2406 | 13848 | 52.88 | 0.9 | 429.94 | 161362.7 |
| May-21 | 62.69 | 19.13 | 14.56 | 6879 | 1170 | 2250 | 10299 | 55.69 | 0.9 | 2239.8 | 138889.9 |
| Jun-21 | 24.71 | 12.38 | 12.05 | 3105 | 1002 | 2013 | 6120 | 53.12 | 0.9 | 5120.6 | 112996.6 |
| Jul-21 | 31.4 | 12.19 | 12.23 | 3825 | 942 | 1890 | 6657 | 52.71 | 0.9 | 4332.7 | 115964.7 |
| Aug-21 | 49.1 | 13.41 | 12.46 | 6045 | 981 | 1983 | 9009 | 51.27 | 0.9 | 4186.7 | 131817.6 |
| Sep-21 | 54.08 | 13.55 | 13.35 | 5595 | 1050 | 2121 | 8766 | 49.45 | 0.9 | 4616.9 | 130584.4 |
| Oct-21 | 65.38 | 15.41 | 12.57 | 7059 | 1026 | 2004 | 10089 | 47.89 | 0.8 | 2818.2 | 137959.2 |
| Nov-21 | 64.76 | 13.72 | 13.39 | 7728 | 1092 | 2148 | 10968 | 48.24 | 0.8 | 3062.6 | 144199.9 |
| Dec-21 | 85.65 | 19.39 | 14.98 | 9807 | 1071 | 2040 | 12918 | 58.4 | 0.9 | 1605 | 156202.6 |
| Jan-22 | 108.65 | 19.04 | 17.77 | 11814 | 1218 | 2316 | 15348 | 71.27 | 0.9 | 1906.9 | 173168.5 |

INFERENCE

1. Overall consumption is low as the college was not functioning during the pandemic period and lack of occupancy for a major part of the year.
2. Consumption is picking up in the last 3 months as the college has partially reopened.

SUGGESTION

1. There is huge potential for more capacity utilization and future expansion considering the overall contract demand of 200kVA and available transformer of 500kVA capacity.




6. ENERGY PERFORMANCE

1. ANNUAL ENERGY CONSUMPTION – FEB 2021- JAN 2022

Table 5: Energy distribution

| Particulars | Unit | Quantity | GCV (Kcal) | Tonne of Oil Equivalent (Toe) | % Distribution |
|--------------|--------|----------|------------|-------------------------------|----------------|
| Electricity | kWh | 128127 | 860 | 11.02 | 95.74 |
| Diesel | Litres | 200 | 10800 | 0.22 | 1.57 |
| LPG | Kg | 247 | 10990 | 0.27 | 1.93 |
| Total | | | | 11.51 | |



INFERENCE

- Major Energy Consumption source is Electricity which is 96 % of the total energy consumption.

2. ANNUAL ENERGY COST –FEB 2021 TO JAN 2022


Table 6: Energy distribution

| Particulars | Unit | Quantity | Cost/Unit | Average Cost (Lakhs) | % Distribution |
|--------------|----------|----------|-----------|----------------------|----------------|
| Electricity | kWh | 128127 | 6.72 | 8.61 | 95.03 |
| Diesel | Litres | 200 | 92.27 | 0.18 | 1.99 |
| LPG | Cylinder | 13 | 2113 | 0.27 | 2.98 |
| Total | | | | 9.06 | |



(Handwritten signature in green ink)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18



INFERENCE

1. 95% of the total energy cost is expended on electricity.

3. ENERGY PERFORMANCE INDEX

Energy Performance Index (EPI) is the key metric used for benchmarking energy usage in commercial building. EPI is the energy used per unit area measured as kWh/m²/year or kWh/person/year.

EPI is calculated for the year 2019 considering normal consumption trend before the pandemic started and after implementation of energy saving measures listed in the executive summary.

Table 7: Energy performance index

| Particulars | Annual EB Energy Consumption | Annual DG Energy Consumption | Build-up Area (m ²) | EPI |
|----------------------|------------------------------|------------------------------|---------------------------------|--------------------------|
| Unit | kWh/year | kWh/Year | m ² | kWh/annum/m ² |
| Year 2019 | 237558 | 2512 | 18985 | 12.65 |
| After Implementation | 185819 | 2512 | 18985 | 9.92 |
| Reduction % | 21.78 | 0 | 0 | 21.59 |

INFERENCE

1. The overall EPI Value can decrease by 21.59 % if the energy saving measures are implemented.



[Handwritten Signature]

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18


7. ENERGY PERFORMANCE ASSESSMENT OF MAJOR EQUIPMENTS

MEASURED LOAD MATRIX

Table 8: Measured Load Share

| LOAD CATEGORY | LOAD (kW) | % LOAD |
|------------------------|--------------|------------|
| Lighting | 55.5 | 8.34 |
| Ventilation | 41.6 | 6.24 |
| Computer & Peripherals | 54.3 | 8.15 |
| Air Conditioner | 146.7 | 22.04 |
| Other Appliances | 4 | 0.61 |
| Lab Equipment | 363.4 | 54.61 |
| TOTAL | 665.5 | 100 |

Measured Load Share



INFERENCE

1. Major share of the load is accounted to lab equipment while Air conditioning accounts to 22%.
2. Lighting, Ventilation and Computer accessories have nearly an equal load share.



(Handwritten signature in green ink)


PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

ESTIMATED ENERGY SHARE FOR DIFFERENT LOADS

Table 9: Estimated Energy Share

| Estimated Annual Energy Consumption | | |
|-------------------------------------|------------------|-------------|
| Particulars | Energy (kWh) | Percentage |
| Lighting | 44108.30 | 23% |
| Ventilation* (Fan) | 51252.65 | 26.72% |
| Computer & Peripherals | 22918.90 | 11.95% |
| Air Conditioner | 55264.74 | 28.82% |
| Other Appliances | 3098.5 | 1.62% |
| Lab Equipment | 15142.92 | 7.90% |
| TOTAL | 191786.02 | 100% |

*Ventilation equipment includes ceiling fans, wall fans, pedestal fan and exhaust fan



INFERENCE

1. Lighting, Ventilation and Air conditioning have nearly equal Energy usage for which energy saving recommendations are listed in the executive summary.
2. Though lab equipment accounts to major load share, Energy share is comparatively less due to less usage.



[Handwritten Signature]

PRINCIPAL
Sree Chitra Thirunal
College of Engineering 19
Trivandrum - 18

LIST OF EQUIPMENT OR PROCESS WHERE PERFORMANCE ASSESSMENT WAS DONE

- I. ELECTRICAL SYSTEM
- II. DIESEL GENERATOR
- III. HVAC & VENTILATION
- IV. LIGHTING SYSTEM

I. ELECTRICAL SYSTEM

MAIN LOGGING OF TRANSFORMER SECONDARY SIDE


The secondary side of transformer (500kVA) was logged with power logger HIOKI PW3360 for 24 hours during the period – 09th February 2022 to 10th February 2022 (Measurement averaging period is 5 minutes) and the obtained data is summarized below:

Table 10: Transformer details

| MAIN LOGGING DATA AT TRANSFORMER SECONDARY | | | | |
|--|-------|----------|---------|---------|
| Particulars | Units | Data | | |
| Transformer Rating | kVA | 500 | | |
| Voltage ratings | kV | 11/0.433 | | |
| % Impedance | % | 4.6 | | |
| Year of manufacture | | 2013 | | |
| MEASUREMENT VALUES | | | | |
| Actual Energy for 24 hours | kWh | 731.46 | | |
| Average power factor | | 0.86 | | |
| Particulars | Units | Minimum | Maximum | Average |
| Active power | kW | 7.86 | 90.15 | 30.68 |
| Apparent power | kVA | 9.33 | 93.63 | 32.51 |
| Reactive power | kVAr | -5.89 | 28.14 | 8.86 |
| Voltage line | V | 239.17 | 248.18 | 243.66 |
| Current ratings | Amps | 8.94 | 139 | 45.76 |

INFERENCE

1. The power factor is 0.86 lagging during the audit period.
2. The Maximum demand registered during the period is 93.63 kVA, in 5 minutes interval.
3. The maximum and average loading of the transformer were 18.72 % and 6.5% respectively in the 24 hours period.



(Handwritten signature in green ink)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

1. TRANSFORMER

A 500kVA transformer is installed in the facility, the load study was carried out with the following observations:




Fig 1: Transformer

| Table 11: TRANSFORMER - LOSS ESTIMATION | | |
|---|------|----------|
| Reference period - 3.24pm 09/02/22 to 3.24pm 10/02/22 | | |
| Particulars | Unit | Quantity |
| HT Side Consumption (From TOD Meter) | kWh | 738 |
| Total Energy Consumption on LT Side | kWh | 731.46 |
| Total loss in transformer | % | 0.89 |
| Energy loss per day | kWh | 6.54 |
| Annual Energy loss | kWh | 2387.1 |

INFERENCE

1. Between the TOD meter installed by KSEB and three phase power analyser installed in the LT mains, a difference of 6.54 kWh/day has been found. This is the loss in energy in between the Transformer HT side and LT substation input side. The loss is well within the allowable limits.



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18¹

2. ANALYSIS: VOLTAGE VARIATION

The Voltage profile at the transformer secondary side is plotted below:



INFERENCE


1. The figure shows minimum voltage imbalance and supply voltage variation.
2. The maximum and minimum supply voltage were 248.45 volts and 237.18 volts respectively with an average line voltage of 241.56 volts during the 24-hour logging period.



PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

3. ANALYSIS: CURRENT VARIATIONS

The current profile at all phases at the transformer secondary side is plotted below:



INFERENCE

1. The maximum and the minimum current during the 24 hours logging period are 139 A and 8.94 A respectively.
2. The major consumption is during the day time.



(Handwritten signature)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

3. LOAD FACTOR

The load factor is the ratio of the energy consumed during a given period (During the audit period or last 12 months) to the energy which would have been consumed if maximum demand was maintained throughout the period.

$$\text{Load factor (\%)} = \frac{\text{Energy used during the period (kWh)} \times 100}{\text{Maximum demand (kW)} \times \text{Time under consideration (hours)}}$$

Load factor is calculated for the 24 hours logging at the transformer secondary side in the table below:

Table 12: Load details

| Zone | Total kWh | Max kW | Time (hours) | Load factor % |
|---------------|-----------|--------|--------------|---------------|
| Normal time | 606 | 90.15 | 12 | 56.02 |
| Peak time | 40 | 11.61 | 4 | 86.14 |
| Off-Peak time | 78 | 10.99 | 8 | 88.72 |

INFERENCE


1. Load factor is found to be low for the normal time.
2. The best load factor is in the range of 80% to 100% for a commercial establishment.



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

4. POWER FACTOR

The power factor variation with respect to kW Load is shown in the figure below:



INFERENCE

1. There is average power factor during the time of audit is 0.86.
2. The power factor is found to be low and hence can result in penalties.

SUGGESTIONS

1. Replace/ Repair the deteriorated capacitors from the APFC panels.



[Handwritten Signature]
 PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

5. AUTOMATIC PF CONTROL PANEL

The performance assessment of the APFC Panel is shown in the table below:




Fig 2: APFC Panel

Table 13: APFC PERFORMANCE ASSESSMENT

| Name | Rated KVAR | Design Voltage | Measured Voltage | Measured KVAR | KVAR wrt Voltage | %Deterioration |
|------|------------|----------------|------------------|---------------|--------------------|-------------------|
| | A | B | C | E | $F=A*(C/B)^2$ | $G=(F-E)*(100/F)$ |
| C1 | 25 | 440 | 415 | 21 | 22.24 | 5.58 |
| C2 | 25 | 440 | 415 | 21.76 | 22.24 | 2.16 |
| C3 | 20 | 440 | 415 | 17.66 | 17.8 | 0.79 |
| C4 | 20 | 440 | 415 | | Not working | |
| C5 | 15 | 440 | 415 | 11.23 | 13.35 | 15.89 |
| C6 | 15 | 440 | 415 | 13.14 | 13.35 | 1.58 |
| C7 | 10 | 440 | 415 | | Not working | |
| C8 | 10 | 440 | 415 | | Not working | |
| C9 | 10 | 440 | 415 | 7.39 | 8.9 | 16.97 |
| C10 | 10 | 440 | 415 | | Fixed compensation | |

INFERENCE

1. Power factor is found to be low due to failure of capacitors in the APFC Panel.
2. The contactors used in the panel are MNX series which are inductor duty contactors.







Figure 3: Capacitor

SUGGESTIONS

1. Replace/ Repair the deteriorated capacitors in the APFC Panel to improve the power factor to avoid penalties and fetch incentives in the Energy bill.
2. Change the contactors to capacitive duty contactors to avoid failures.



II. DIESEL GENERATOR

The 125kVA diesel generator set performance analysis was done with the following observations:




Figure 4: Diesel Generator

| Table 14: DG PERFORMANCE ASSESSMENT | | |
|--|-----------|----------|
| Reference date - 10/02/22 | | |
| TEST DATA | | |
| Particulars | Unit | Quantity |
| Average kVA Measured | kVA | 40 |
| DG Rating | kVA | 125 |
| Test run duration | Minutes | 15 |
| Energy generated during test run | kWh | 18.28 |
| Diesel consumed | Litres | 7.68 |
| INFERENCES | | |
| Specific Energy Generation | kWh/litre | 2.39 |
| Percentage loading (Observed kVA/Rated kVA) | % | 32 |

INFERENCE

1. The specific Energy Generation of DG is 2.39 kWh/ Litre which will improve when the loading is increased above 80%.

III. HVAC & VENTILATION

The following table shows the split up of different HVAC Loads installed in the entire facility:

Table 15: Building wise HVAC load

| SL.NO | APPLIANCE | Window AC | Non Star AC 1T | Non Star AC 1.5T | Non Star AC 2T | 3 Star AC 2T | 5 Star AC 2T | 5 Star AC 1.5T | 3 Star AC 1.5T |
|-------|---|-----------|----------------|------------------|----------------|--------------|--------------|----------------|----------------|
| | Name of Building/Room/Place/Area/Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| 1 | Canteen | | | 1 | | 14 | 2 | | |
| 2 | CGPU Building | | | 1 | | | | 1 | 2 |
| 3 | College Building | | 6 | 4 | | 11 | | | 7 |
| 4 | Lab Building 2 | | | | 1 | 1 | | | 2 |
| 5 | Lab Building | 8 | | 1 | | 4 | | | 2 |
| 6 | Post Office Building | | | 1 | | | | | 2 |
| | Total Nos. | 8 | 6 | 8 | 1 | 30 | 2 | 1 | 15 |

Table 16: Building wise Ventilation load

| SL.NO | APPLIANCE | Exhaust Fan (60W) | Exhaust Fan (40W) | Pedestal Fan (55W) | Pedestal Fan 200W | Pedestal Fan 180W | Wall Fan (50W) | Wall Fan 80W | Ceiling Fan (60W) |
|-------|---|-------------------|-------------------|--------------------|-------------------|-------------------|----------------|--------------|-------------------|
| | Name of Building/Room/Place/Area/Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| 1 | Canteen | 3 | | | | | 11 | | 50 |
| 2 | CGPU Building | | | 1 | | | 3 | | |
| 3 | College Building | 31 | 12 | 1 | | | 26 | | 371 |
| 4 | Lab Building 2 | | | | | | 6 | | 10 |
| 5 | Lab Building | 4 | | 4 | 4 | 2 | 25 | 5 | 102 |
| 6 | Post Office Building | | | | | | 1 | | 16 |
| | Total Nos. | 38 | 12 | 6 | 4 | 2 | 72 | 5 | 549 |



Table 17: Sample Performance Analysis on 2 Air Conditioners

| Location | | Digital Library | Skill Delivery Platform |
|---|--------------------|-----------------|-------------------------|
| Type | | Split | Split |
| Installed Capacity | TR | 2 | 2 |
| Area | m ² | 0.095 | 0.084 |
| Air flow | m ³ /hr | 680.58 | 1235 |
| Density of Air | kg/m ³ | 1.225 | 1.225 |
| Inlet Enthalpy, H ₂ | Kcal/kg | 15.48 | 15.11 |
| Outlet Enthalpy, H ₁ | Kcal/kg | 9.91 | 11.68 |
| Enthalpy difference, Δh=H ₂ -H ₁ | Kcal/kg | 5.57 | 3.43 |
| Cooling Capacity | Kcal/hr | 4640 | 5190 |
| Effective Load | TR | 1.53 | 1.72 |
| Cooling in Watts | W | 5386 | 6024 |
| Power in Watts | W | 1564 | 1792 |
| EER | | 3.44 | 3.36 |
| Rated EER | | 3.6 | 3.72 |
| Performance Assessment | | Healthy | Good |

INFERENCE

1. The annual energy consumption of the inefficient NON-STAR old Air conditioning units account to 13002 kWh annually which upon replacement with efficient BEE Star labelled AC units with total annual consumption of 8428.5 kWh as per recommendations in Executive Summary can yield **Energy Savings of 4573.5 kWh annually**.
2. The annual energy consumption of inefficient ordinary fan units account to 48287 kWh annually which upon replacement with efficient BLDC Fan units with total annual consumption of 22366 kWh as per recommendations in Executive Summary can yield **Energy Savings of 25921 kWh annually**.



IV. LIGHTING SYSTEM

The following table shows the split up of different Light Loads installed in the entire facility:

Table 18: Building wise light loads

| APPLIANCE | T12 (52W) | T12X2 (104W) | T8 (36W) | CFL 70 W | CFL (14W) | LED Spot (12W) | LED Panel 40W | LED Panel – Square (15W) | LED Panel – Round (15W) | LED Tube (18W) | LED Tube 9W | LED Bulb (9W) |
|--|--------------|-----------------|-------------|----------------|--------------|----------------------|---------------------|-----------------------------------|----------------------------------|----------------------|-------------------|---------------------|
| Name of Building/Room /Place/Area/Lo cation | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| Canteen | 37 | 44 | | | 4 | | | | 2 | 31 | | |
| CGPU Building | | 7 | | | 1 | | | | 15 | | | 2 |
| College Building | 226 | 88 | 1 | | 1 | | 20 | 42 | 218 | 63 | 7 | 37 |
| Lab Building 2 | 9 | | | | | | | 20 | | 12 | | |
| Lab Building | 124 | 94 | 8 | 6 | | 12 | | 12 | | 47 | | 2 |
| Post Office Building | 14 | | 3 | | | | | | | 12 | | 3 |
| Total Nos. | 410 | 233 | 12 | 6 | 6 | 12 | 20 | 74 | 235 | 165 | 7 | 44 |

INFERENCE

1. The annual energy consumption of inefficient ordinary lighting system (T12, T12X2, CFL, T8) account to 38319 kWh annually which upon replacement with efficient LED Lights with total annual energy consumption of 13373 kWh as per recommendations in Executive Summary can yield **Energy Savings of 24947 kWh annually**.



8. POWER QUALITY ASSESSMENT

Power quality assessment involves the study of harmonics in an electrical system. **Harmonics** are described by IEEE as sinusoidal voltages or currents having frequencies that are integer multiples of the fundamental frequency at which the power system is designed to operate. This means that for a 50-Hz system, the harmonic frequencies are 100 Hz (2nd harmonic), 150 Hz (3rd harmonic) and so on. Harmonics combine with the fundamental voltage or current producing a non-sinusoidal shape, thus, a waveform distortion power quality problem. The non-sinusoidal shape corresponds to the sum of different sine waves with different magnitudes and phase angles, having frequencies that are multiples of the system frequency.

Harmonic distortion levels can be characterized by the complete harmonic spectrum with magnitudes and phase angles of each individual harmonic component. It is also common to use the Total Harmonic Distortion (THD), as a measure of the effective value of harmonic distortion. It has become an increasing concern for many end-users and for the overall power system because of the growing application of power electronics equipment. Protection from high levels of harmonics includes isolation or modification of the source, phase multiplication, pulse width modulator (PWM) and application of passive or active harmonic filters.

Causes

Harmonics exists due to the nonlinear characteristics loads and devices on the electrical power system. These devices can be modeled as current sources that inject harmonic currents into the electrical system. Consequently, voltage distortion is created as these currents produce nonlinear voltage drops across the system impedance.

Prior to the proliferation of power electronic equipment, harmonics are commonly caused by electric machines working above the knee of the magnetization curve (magnetic saturation), arc furnaces, welding machines, rectifiers, and DC brush motors. Today, all non-linear loads, such as power electronics equipment including Switched Mode Power Supplies (SMPS), Adjustable Speed Drives (ASD), high efficiency lighting and data processing equipment.



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

HARMONICS DATA SHEET

| Table 1.9 Maximum Harmonic Current Distortion in % of IL | | | | | | |
|--|------|------------------|------------------|------------------|-------------|------|
| Individual Harmonic Order (Odd Harmonics) | | | | | | |
| Isc/IL | <11 | $11 \leq h < 17$ | $17 \leq h < 23$ | $23 \leq h < 35$ | $35 \leq h$ | TDD |
| < 20* | 4.0 | 2.0 | 1.5 | 0.6 | 0.3 | 5.0 |
| 20 < 50 | 7.0 | 3.5 | 2.5 | 1.0 | 0.5 | 8.0 |
| 50 < 100 | 10.0 | 4.5 | 4.0 | 1.5 | 0.7 | 12.0 |
| 100 < 1000 | 12.0 | 5.5 | 5.0 | 2.0 | 1.0 | 15.0 |
| > 1000 | 15.0 | 7.0 | 6.0 | 2.5 | 1.4 | 20.0 |

Even harmonics are limited to 25% of the odd current harmonic limits above.

Current distortions that result in a direct current offset, e.g. half wave converters are not allowed.

*All power generation equipment is limited to these values of current distortion, regardless of actual Isc/IL.

Where,

Isc = Maximum short circuit current at PCC.

I_L = Maximum Demand Load Current (fundamental frequency component) at PCC.

TDD = Total demand distortion (RSS), harmonic current distortion in % of maximum demand load current (15 or 30 min demand).


| Table 1.10 Total Harmonic Distribution for Different Voltage Levels in % | | |
|--|-----------------------------------|----------------------------------|
| Bus Voltage at PCC | Individual Voltage Distortion (%) | Total Voltage Distortion THD (%) |
| 69 kV and below | 3.0 | 5.0 |
| 69.001 kV Thru 161 kV | 1.5 | 2.5 |
| 161 kV and above | 1.0 | 1.5 |



PRINCIPAL
Sree Chitra Thirunal
College of Engineering³³
Trivandrum - 18

Table 19: THD Details

| Location | | | | Incoming 11 KV secondary side | | | |
|---|------|-----------|-----------|--|------|------|------|
| Total harmonic distortion as per CEA standard TDDi limit is 8% and THDv limit is 5% as per short circuit analysis | | | | | | | |
| Total harmonic distortion | | Voltage % | Current % | Remarks | | | |
| | | 2.29 | 11.94 | Current harmonics are found to be high | | | |
| Individual harmonics % | | | | | | | |
| Particulars | 3rd | 5th | 7th | 9th | 11th | 13th | 15th |
| Voltage % | 0.23 | 1.94 | 0.79 | 0.17 | 0.65 | 0.22 | 0.25 |
| Current % | 7.58 | 5.15 | 4.07 | 2.64 | 3.64 | 1.64 | 2.02 |



INFERENCE


1. The 3rd individual current harmonics level is 7.58 % which is higher than the permissible level of 7%.
2. The Total current harmonic distortion level is 11.94 % which is higher than the permissible level of 8%.
3. The harmonics are high due to the presence of major non-linear load share in the facility.



[Handwritten Signature]

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

VOLTAGE WAVEFORM




INFERENCE

1. The voltage waveform obtained from the power logger data is steady and continuous.




PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

CURRENT WAVEFORM



INFERENCE

1. The current waveforms are irregular as seen in the graph due to harmonics in the system due to non-linear loads



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

POWER QUALITY DATA FROM POWER LOGGER

Table 20: Power logger data

| Reference period - | | 3.24pm 09/02/22 to 3.24pm | | |
|----------------------|------------------------------|--------------------------------|--------|-----------------------------------|
| Reference document - | | IEEE 519 Standards | | |
| SL NO | Particulars | Analysis Summary | | Inference |
| 1 | Voltage Continuity (Input) | Good | | Normal |
| 2 | RMS Voltage level | R | 241.56 | Normal |
| | | Y | 243.66 | |
| | | B | 243.9 | |
| 3 | Voltage waveforms | Slightly distorted sine waves | | Normal |
| 4 | Dips & Swells | Not recorded during load study | | Normal |
| 5 | Transient voltages | Not recorded during load study | | Normal |
| 6 | Voltage fluctuations/flicker | Not recorded during load study | | Normal |
| 7 | Power factor | 0.86 | | Lagging pf during load study |
| 8 | Load current waveform | Highly distorted sine waves | | Due to non-linear loads connected |
| 9 | Load generated disturbances | Present | | Due to non-linear loads connected |

Table 21: Power logger data

| POWER QUALITY ANALYSIS - THD | | | | | |
|--------------------------------------|--|-------|----------|---------|--|
| SL NO | Harmonic Analysis | Phase | Load (A) | THD (%) | Inference |
| Minimum load (07:34 AM -10/02/22) | | | | | |
| 1 | THD (V) % (Permissible limits<5% as per IEE 519 -2014) | R | 12.96 | 2.07 | Within permissible limit at minimum load during load study |
| | | Y | 16.72 | 2.07 | |
| | | B | 13.17 | 2.19 | |
| 2 | THD (I) % (Permissible limits<8% as per IEE 519 -2014) | R | 12.96 | 50.51 | Above permissible limit at minimum load during load study |
| | | Y | 16.72 | 22.98 | |
| | | B | 13.17 | 45.72 | |
| Maximum load (03.19 PM - 10/02/22) | | | | | |
| 3 | THD (V) % (Permissible limits<5% as per IEE 519 -2014) | R | 129.61 | 2.29 | Within permissible limit at maximum load during load study |
| | | Y | 113.73 | 2.16 | |
| | | B | 139 | 2.46 | |
| 4 | THD (I) % (Permissible limits<8% as per IEE 519 -2014) | R | 129.61 | 11.94 | Above permissible limit at maximum load during load study |
| | | Y | 113.73 | 10.99 | |
| | | B | 139 | 14.47 | |




9. THERMOGRAPHY REPORT

Company Vydyuthi Energy Services **Customer** Sree Chitra Thirunal College of Engineering
 Kowdiar Pappanamcode
 Trivandrum Trivandrum
Tester Shabin Sha

Device testo 865 **Serial** 62799447 **Lens:** 42° x 30°

Task Transformer - Body



Picture **Date:** 09-02-2022 **Emissivity:** 0.95
Time: 16:18:34 **Refl. temp. [°C]:** 20.0
File: SR000030.BMT

Picture markings:

| Measurement | Temp. | Emiss. | Refl. temp. | Remarks |
|-----------------|-------|--------|-------------|-----------------------------------|
| Measure point 1 | 40.5 | 0.95 | 20.0 | CenterSpot |
| Hot spot 1 | 41.7 | 0.95 | 20.0 | No serious hotspots were observed |



Company Vydyuthi Energy Services **Customer** Sree Chitra Thirunal College of Engineering
 Kowdiar Pappanamcode Trivandrum
Tester Shabin Sha

Device testo 865 **Serial** 62799447 **Lens:** 42° x 30°
Task MSB



Picture **Date:** 09-02-2022 **Emissivity:** 0.95
Time: 16:27:50 **Refl. temp. [°C]:** 20.0
File: SR000036.BMT

Picture markings:


| Measurement | Temp. | Emiss. | Refl. temp. | Remarks |
|-----------------|-------|--------|-------------|-----------------------------------|
| Measure point 1 | 32.1 | 0.95 | 20.0 | CenterSpot |
| Hot spot 1 | 34.1 | 0.95 | 20.0 | No serious hotspots were observed |



PRINCIPAL
 Sree Chitra Thirunal College of Engineering
 Trivandrum - 18

Company Vydyuthi Energy Services **Customer** Sree Chitra Thirunal College of Engineering
 Kowdiar Pappanamcode
 Trivandrum Trivandrum
Tester Shabin Sha

Device testo 865 **Serial** 62799447 **Lens:** 42° x 30°
Task Capacitor Panel



Picture **Date:** 10-02-2022 **Emissivity:** 0.95
Time: 12:37:42 **Refl. temp. [°C]:** 20.0
File: SR000037.BMT

Picture markings:

| Measurement | Temp. | Emiss. | Refl. temp. | Remarks |
|-----------------|-------|--------|-------------|-----------------------------------|
| Measure point 1 | 33.8 | 0.95 | 20.0 | CenterSpot |
| Hot spot 1 | 51.0 | 0.95 | 20.0 | No serious hotspots were observed |



PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

10. RECOMMENDATIONS IN DETAIL FOR ENERGY CONSERVATION

MAIN BUILDING

1. Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|--------------|
| Existing T12 Tube Lights | kW | 0.052 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 4.60 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1151 |
| No: of operating T12 Tube lights | Nos | 226 |
| Annual consumption for T12 Tube Lights | KWh | 13529 |
| Annual consumption for LED Tube Lights | KWh | 4683 |
| Unit Savings per annum | KWh | 8846 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 88280 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 90400 |
| Simple Payback period | Years | 1 |

2. Retrofitting of 2x52W (2xT12) ordinary tube light with 2x18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|-----------------|
| Existing T12x2 Tube Lights | kW | 0.104 |
| Proposed LED Tubex2 Light | kW | 0.036 |
| Avg No: of working hours/day | Hours | 6.07 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1517 |
| No: of operating T12x2 Tube lights | Nos | 88 |
| Annual consumption for T12x2 Tube Lights | KWh | 13884 |
| Annual consumption for LED Tubex2 Lights | KWh | 4806 |
| Unit Savings per annum | KWh | 9078 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 90598.44 |
| Cost of LED Tubex2 Lights | Rs | 800 |
| Investment for LED Tubex2 Lights | Rs | 70400 |
| Simple Payback period | Years | 1 |



(Handwritten signature)

3. Retrofitting of 36W (T8) ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|------------|
| Existing T8 Tube Lights | kW | 0.036 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 7.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1750 |
| No: of operating T8 Tube lights | Nos | 1 |
| Annual consumption for T8 Tube Lights | KWh | 63 |
| Annual consumption for LED Tube Lights | KWh | 32 |
| Unit Savings per annum | KWh | 32 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 314 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 400 |
| Simple Payback period | Years | 1 |

4. Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan

| Particulars | Unit | Quantity |
|-------------------------------------|-------|----------------|
| Existing Ceiling fan | kW | 0.06 |
| Proposed BLDC Fan | kW | 0.035 |
| Avg No: of working hours/day | Hours | 5.66 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1415 |
| No: of operating Ceiling Fans | Nos | 371 |
| Annual consumption for Ceiling Fans | KWh | 31501.88 |
| Annual consumption for BLDC Fans | KWh | 18376.09 |
| Unit Savings per annum | KWh | 13126 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 130995 |
| Cost of BLDC Fan | Rs | 3000 |
| Investment for BLDC Fans | Rs | 1113000 |
| Simple Payback period | Years | 8 |



(Handwritten signature in green ink)

5. Retrofitting of existing ordinary and old air conditioner (1.5T) with inverter air conditioner/BEE star rated air conditioner.

| Particulars | Unit | Quantity |
|-------------------------------------|-------|---------------|
| Existing Non star AC 1.5T | kW | 2.364 |
| Proposed BEE Star Rated Inverter AC | kW | 1.5 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating Non star AC | Nos | 4 |
| Annual consumption for Non star AC | KWh | 7092 |
| Annual consumption for 5 Star AC | KWh | 4500 |
| Unit Savings per annum | KWh | 2592 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 25868 |
| Cost of 5 Star AC | Rs | 33000 |
| Investment for 5 Star AC | Rs | 132000 |
| Simple Payback period | Years | 5 |

6. Retrofitting of existing ordinary and old air conditioner (1T) with inverter air conditioner/BEE star rated air conditioner.

| Particulars | Unit | Quantity |
|-------------------------------------|-------|---------------|
| Existing Non star AC 1T | kW | 1.576 |
| Proposed BEE Star Rated Inverter AC | kW | 1.119 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating Non star AC | Nos | 6 |
| Annual consumption for Non star AC | KWh | 7092 |
| Annual consumption for 5 Star AC | KWh | 5036 |
| Unit Savings per annum | KWh | 2057 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 20524 |
| Cost of 5 Star AC | Rs | 30000 |
| Investment for 5 Star AC | Rs | 180000 |
| Simple Payback period | Years | 6 |



(Handwritten signature in green ink)

MAIN LAB BUILDING

7. Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|--------------|
| Existing T12 Tube Lights | kW | 0.052 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 1.25 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 312 |
| No: of operating T12 Tube lights | Nos | 124 |
| Annual consumption for T12 Tube Lights | KWh | 2010 |
| Annual consumption for LED Tube Lights | KWh | 696 |
| Unit Savings per annum | KWh | 1314 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 13117 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 49600 |
| Simple Payback period | Years | 4 |

8. Retrofitting of 2x52W (2xT12) ordinary tube light with 2x18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|--------------|
| Existing T12x2 Tube Lights | kW | 0.104 |
| Proposed LED Tubex2 Light | kW | 0.036 |
| Avg No: of working hours/day | Hours | 1.44 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 360 |
| No: of operating T12x2 Tube lights | Nos | 94 |
| Annual consumption for T12x2 Tube Lights | KWh | 3515 |
| Annual consumption for LED Tubex2 Lights | KWh | 1217 |
| Unit Savings per annum | KWh | 2298 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 22936 |
| Cost of LED Tubex2 Lights | Rs | 800 |
| Investment for LED Tubex2 Lights | Rs | 75200 |
| Simple Payback period | Years | 3 |



9. Retrofitting of 36W (T8) ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|-------------|
| Existing T8 Tube Lights | kW | 0.036 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 2.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 500 |
| No: of operating T8 Tube lights | Nos | 8 |
| Annual consumption for T8 Tube Lights | KWh | 144 |
| Annual consumption for LED Tube Lights | KWh | 72 |
| Unit Savings per annum | KWh | 72 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 719 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 3200 |
| Simple Payback period | Years | 4 |

10. Retrofitting of 14W CFL bulb with 7W LED bulb.

| Particulars | Unit | Quantity |
|---------------------------------|-------|-------------|
| Existing CFL | kW | 0.07 |
| Proposed LED Bulb | kW | 0.04 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating CFL | Nos | 6 |
| Annual consumption for CFL | KWh | 315 |
| Annual consumption for LED Bulb | KWh | 180 |
| Unit Savings per annum | KWh | 135 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 1347 |
| Cost of LED Bulb | Rs | 700 |
| Investment for LED Bulbs | Rs | 4200 |
| Simple Payback period | Years | 3 |



(Handwritten signature in green ink)

11. Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan

| Particulars | Unit | Quantity |
|-------------------------------------|-------|---------------|
| Existing Ceiling fan | kW | 0.06 |
| Proposed BLDC Fan | -kW | 0.035 |
| Avg No: of working hours/day | Hours | 6.50 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1625 |
| No: of operating Ceiling Fans | Nos | 102 |
| Annual consumption for Ceiling Fans | KWh | 9945 |
| Annual consumption for BLDC Fans | KWh | 5801 |
| Unit Savings per annum | KWh | 4144 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 41355 |
| Cost of BLDC Fan | Rs | 3000 |
| Investment for BLDC Fans | Rs | 306000 |
| Simple Payback period | Years | 7 |

12. Retrofitting of existing ordinary and old air conditioner (1.5T) with inverter air conditioner/BEE star rated air conditioner.

| Particulars | Unit | Quantity |
|-------------------------------------|-------|--------------|
| Existing Non star AC 1.5T | kW | 2.364 |
| Proposed BEE Star Rated Inverter AC | kW | 1.5 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating Non star AC | Nos | 1 |
| Annual consumption for Non star AC | KWh | 1773 |
| Annual consumption for 5 Star AC | KWh | 1125 |
| Unit Savings per annum | KWh | 648 |
| Cost per kWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 6467 |
| Cost of 5 Star AC | Rs | 33000 |
| Investment for 5 Star AC | Rs | 33000 |
| Simple Payback period | Years | 5 |



CANTEEN BUILDING

13. Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|--------------|
| Existing T12 Tube Lights | kW | 0.052 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 2.26 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 564.68 |
| No: of operating T12 Tube lights | Nos | 37 |
| Annual consumption for T12 Tube Lights | KWh | 1086 |
| Annual consumption for LED Tube Lights | KWh | 376 |
| Unit Savings per annum | KWh | 710 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 7089 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 14800 |
| Simple Payback period | Years | 2 |

14. Retrofitting of 2x52W (2xT12) ordinary tube light with 2x18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|--------------|
| Existing T12x2 Tube Lights | kW | 0.104 |
| Proposed LED Tubex2 Light | kW | 0.036 |
| Avg No: of working hours/day | Hours | 2.65 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 663 |
| No: of operating T12x2 Tube lights | Nos | 44 |
| Annual consumption for T12x2 Tube Lights | KWh | 3035 |
| Annual consumption for LED Tubex2 Lights | KWh | 1051 |
| Unit Savings per annum | KWh | 1984 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 19805 |
| Cost of LED Tubex2 Lights | Rs | 800 |
| Investment for LED Tubex2 Lights | Rs | 35200 |
| Simple Payback period | Years | 2 |



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

15. Retrofitting of 14W CFL bulb with 7W LED bulb.

| Particulars | Unit | Quantity |
|---------------------------------|-------|------------|
| Existing CFL | kW | 0.014 |
| Proposed LED bulb | kW | 0.007 |
| Avg No: of working hours/day | Hours | 2.08 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 521 |
| No: of operating CFL | Nos | 4 |
| Annual consumption for CFL | KWh | 29 |
| Annual consumption for LED bulb | KWh | 15 |
| Unit Savings per annum | KWh | 15 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 146 |
| Cost of LED bulb | Rs | 120 |
| Investment for LED bulb | Rs | 480 |
| Simple Payback period | Years | 3 |

16. Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan

| Particulars | Unit | Quantity |
|-------------------------------------|-------|---------------|
| Existing Ceiling fan | kW | 0.06 |
| Proposed BLDC Fan | kW | 0.035 |
| Avg No: of working hours/day | Hours | 6.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1500 |
| No: of operating Ceiling Fans | Nos | 50 |
| Annual consumption for Ceiling Fans | KWh | 4500 |
| Annual consumption for BLDC Fans | KWh | 2625 |
| Unit Savings per annum | KWh | 1875 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 18713 |
| Cost of BLDC Fan | Rs | 3000 |
| Investment for BLDC Fans | Rs | 150000 |
| Simple Payback period | Years | 8 |



(Handwritten signature in green ink)

POST OFFICE BUILDING

17. Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|-------------|
| Existing T12 Tube Lights | kW | 0.052 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750.00 |
| No: of operating T12 Tube lights | Nos | 14 |
| Annual consumption for T12 Tube Lights | KWh | 546 |
| Annual consumption for LED Tube Lights | KWh | 189 |
| Unit Savings per annum | KWh | 357 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 3563 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 5600 |
| Simple Payback period | Years | 2 |

18. Retrofitting of 36W (T8) ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|-------------|
| Existing T8 Tube Lights | kW | 0.036 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating T8 Tube lights | Nos | 3 |
| Annual consumption for T8 Tube Lights | KWh | 81 |
| Annual consumption for LED Tube Lights | KWh | 41 |
| Unit Savings per annum | KWh | 41 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 404 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 1200 |
| Simple Payback period | Years | 3 |



19. Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan

| Particulars | Unit | Quantity |
|-------------------------------------|-------|--------------|
| Existing Ceiling fan | kW | 0.06 |
| Proposed BLDC Fan | kW | 0.035 |
| Avg No: of working hours/day | Hours | 6.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1500 |
| No: of operating Ceiling Fans | Nos | 16 |
| Annual consumption for Ceiling Fans | KWh | 1440 |
| Annual consumption for BLDC Fans | KWh | 840 |
| Unit Savings per annum | KWh | 600 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 5988 |
| Cost of BLDC Fan | Rs | 3000 |
| Investment for BLDC Fans | Rs | 48000 |
| Simple Payback period | Years | 8 |

SECOND LAB BUILDING

20. Retrofitting of 52W (T12) Ordinary tube light with 18W LED tube light.

| Particulars | Unit | Quantity |
|--|-------|-------------|
| Existing T12 Tube Lights | kW | 0.052 |
| Proposed LED Tube Light | kW | 0.018 |
| Avg No: of working hours/day | Hours | 1.33 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 333 |
| No: of operating T12 Tube lights | Nos | 9 |
| Annual consumption for T12 Tube Lights | KWh | 156 |
| Annual consumption for LED Tube Lights | KWh | 54 |
| Unit Savings per annum | KWh | 102 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 1018 |
| Cost of LED Tube Lights | Rs | 400 |
| Investment for LED Tube Lights | Rs | 3600 |
| Simple Payback period | Years | 4 |



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

21. Retrofitting of existing inefficient ceiling fan with BEE 5 star rated (BLDC) ceiling fan

| Particulars | Unit | Quantity |
|-------------------------------------|-------|----------------|
| Existing Ceiling fan | kW | 0.06 |
| Proposed BLDC Fan | kW | 0.035 |
| Avg No: of working hours/day | Hours | 6.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 1500 |
| No: of operating Ceiling Fans | Nos | 10 |
| Annual consumption for Ceiling Fans | KWh | 900 |
| Annual consumption for BLDC Fans | KWh | 525 |
| Unit Savings per annum | KWh | 375.00 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 3742.50 |
| Cost of BLDC Fan | Rs | 3000 |
| Investment for BLDC Fans | Rs | 30000 |
| Simple Payback period | Years | 8 |

22. Retrofitting of existing ordinary and old air conditioner (2T) with inverter air conditioner/BEE star rated air conditioner.

| Particulars | Unit | Quantity |
|-------------------------------------|-------|--------------|
| Existing Non star AC 2T | kW | 3.152 |
| Proposed BEE Star Rated Inverter AC | kW | 2.238 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating Non star AC | Nos | 1 |
| Annual consumption for Non star AC | KWh | 2364 |
| Annual consumption for 5 Star AC | KWh | 1679 |
| Unit Savings per annum | KWh | 686 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 6841 |
| Cost of 5 Star AC | Rs | 42000 |
| Investment for 5 Star AC | Rs | 42000 |
| Simple Payback period | Years | 6 |



CGPU BUILDING

23. Retrofitting of 14W CFL with 7W LED bulb

| Particulars | Unit | Quantity |
|---------------------------------|-------|--------------|
| Existing CFL | kW | 0.014 |
| Proposed LED bulb | kW | 0.007 |
| Avg No: of working hours/day | Hours | 2.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 500 |
| No: of operating CFL | Nos | 1 |
| Annual consumption for CFL | KWh | 7.00 |
| Annual consumption for LED bulb | KWh | 3.50 |
| Unit Savings per annum | KWh | 3.50 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 34.93 |
| Cost of LED bulb | Rs | 120 |
| Investment for LED bulb | Rs | 120 |
| Simple Payback period | Years | 3 |

24. Retrofitting of existing ordinary and old air conditioner (1.5T) with inverter air conditioner/BEE star rated air conditioner.

| Particulars | Unit | Quantity |
|-------------------------------------|-------|--------------|
| Existing Non star AC 1.5T | kW | 2.364 |
| Proposed BEE Star Rated Inverter AC | kW | 1.5 |
| Avg No: of working hours/day | Hours | 3.00 |
| No: of working days per year | Days | 250 |
| No: of working hours per annum | Hours | 750 |
| No: of operating Non star AC | Nos | 1 |
| Annual consumption for Non star AC | KWh | 1773 |
| Annual consumption for 5 Star AC | KWh | 1125 |
| Unit Savings per annum | KWh | 648 |
| Cost per KWh(Average) | Rs | 9.98 |
| Annual financial savings | Rs | 6467 |
| Cost of 5 Star AC | Rs | 33000 |
| Investment for 5 Star AC | Rs | 33000 |
| Simple Payback period | Years | 5 |



25. Power factor optimization from 0.87 to 1

| Particulars | Unit | Quantity |
|--|--------|----------------|
| Average annual Recorded maximum demand | KVA | 52.33 |
| Present power factor (lagging) | | 0.88 |
| Average KW Drawn | KW | 46.06 |
| KVAr required for PF Improvement to 1 from 0.88 (multiplication factor 0.54 Ref :BEE Table) | KVAr | 24.87 |
| Assumed cost per KVAr for new capacitors | Rs | 900 |
| Total Cost for Capacitors / existing repair | Rs | 22383 |
| Power factor after PF Optimisation (Correcting the faulty capacitors or new capacitor panel) | | 1 |
| Maximum demand at 1 PF | KVA | 46.06 |
| Reduction in Maximum demand | KVA | 6.27 |
| Percentage reduction in energy charge from 0.88 to 1 PF Improvement @0.5% for every 0.01 increase | % | 6 |
| Annual Electricity consumption | KWh | 128127 |
| Monthly average electricity consumption | KWh | 10677.25 |
| Assumed per unit energy charge | Rs | 6.22 |
| Monthly average energy charge cost component | Rs | 66413 |
| Cost reduction in pf penalty/incentive per month due to pf improvement (6% of energy charge component) | Rs | 3984.78 |
| Annual Cost reduction (a) | Rs | 47818 |
| Monthly Cost savings by MD reduction at Rs 440/KVA | Rs | 2758.8 |
| Annual Cost savings by MD reduction at Rs 440/KVA (b) | Rs | 33105.6 |
| Total annual savings (a)+(b) | Rs | 80923.6 |
| Simple Payback period | months | 4 |

INFERENCE

1. Annual Energy Savings of Rs 80924 is obtained at an investment of Rs 22383 which can be gained back in a payback period of 4 months.
2. The deteriorated capacitors can be replaced or repaired as per the analysis given in APFC performance assessment chart.



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

OTHER RECOMMENDATIONS



Figure 5: Air-conditioned rooms being kept open

OBSERVATION – Doors of Air-conditioned lab area is kept open while AC is switched on.

SUGGESTION–Close the doors/ensure proper air curtains are installed to prevent wastage.





Figure 6: Insufficient number of AC's

OBSERVATION – Insufficient number of split AC units for large lab areas.

SUGGESTION– Add more AC units with optimal design to ensure AC compressor cut-off at regular intervals.




PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum 55 18



OBSERVATION – Natural ventilation and day light is blocked with cupboard and all inefficient T12 tube lights are functioning.

SUGGESTION – Ensure natural ventilation and day light is optimally used.


Figure 7: Inefficient Fluorescent tube lights in lab building



Figure 8: Lack of heat exhaust systems in lab building

OBSERVATION – High temperatures inside the lab area due to lack of heat exhaust systems and improper day light usage.

SUGGESTION–Natural draft exhaust fans can be installed which will reduce the indoor heat. There is huge potential for day light use in the lab building which can be tapped with transparent roofing sheets.



PRINCIPAL⁵⁶
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

Recommendations for Air Conditioning system:

1. Replace the inefficient ACs like non-Star split ACs, which will result in energy savings.
2. Maintenance of Air Conditioners should be done regularly to get better AC output.
3. Keep the Air Conditioned rooms air tight and avoid the temperature increase inside the room, due to the sunlight penetration by using curtains/ sun films /Low E-glass windows/multi pane windows.
4. The connection pipes of outdoor and indoor units of ACs, are to be maintained with proper insulation.
5. Existing windows can be replaced with energy efficient windows (high R value, low solar heat gain coefficient, low conductivity, low emissivity glazing, air tight etc.)
6. Set the air conditioning temperature within a range of 24-26 degree Celsius, to have better human comfort and hence to save power.
7. Create awareness among employees about the importance and practice of Energy Conservation.

Recommendations for Ventilation system:

1. Replace the existing fans with BEE 5 star labelled (BLDC) ceiling fans.
2. Fans may be cleaned regularly.
3. Switch off Fans, when not in use and adjust the regulator position to attain optimal speed.
4. Fans, once damaged and obsolete, may be replaced with new and energy efficient BEE 5 star rated fan, rather than rewinding them. Rewinding causes heat loss.
5. Utilize natural wind, to the maximum extent possible.
6. Create awareness among employees about the importance and practice of Energy Conservation.

Recommendations for lighting system:

1. Utilize Day light to maximum extent possible.
2. Replace 28W Fluorescent Tube lights (T5) with 18W LED tube.
3. Replace CFL with 14W / 7W LED bulb.
4. Clean the light fittings and Window panes regularly. A heavy coat of dust on fittings can block up to 50% of the light output.
5. For lighting control, use suitable occupancy sensors/timers/motion sensors, to get the light, as per the requirement. Lighting costs can be reduced up to 40%.
6. Switch off the energy using appliances/ equipment, when not in use.
7. Switch on only the necessary lights, as and when required. Turn off lights in unoccupied spaces.
8. Create awareness among employees about the importance and practice of Energy Conservation.

Recommendations for computers:

1. Switch off the supply to the computers at the switch board when not in use.
2. Shut down computers, when not in use, especially during lunch hours etc.



PRINCIPAL
Sree Chitra Thirunal⁵⁷
College of Engineering
Trivandrum - 18

11. CLIMATE IMPACT

Climate change is disrupting the economies and lives of people in every country in every continent. In recent years, Kerala has seen the worst changing weather patterns, rising sea levels and greenhouse gas emissions are now at the highest levels in history. Wildfires, floods and temperature rises have become a threat to the state of Kerala. Greenhouse gases dominated by Carbon di-oxide emission is the major reason for global warming and consequent climate change and carbon accounting provides a quantification of greenhouse gas emitted by the organization. In carbon accounting the major reasons of carbon emission within the organisation are identified and quantification of the weight of carbon dioxide emitted is done based on scientific calculations and standard assumptions.

Emission due to Electrical Energy Usage

Every unit of electricity consumption is associated with carbon emission according to the methods of power generation in the utility grid of the region According to Indian grid standards, 0.79 kgCO₂ is emitted per kWh of electricity generated.

CO₂ emissions due to electricity consumption [kg]

$$= \text{Grid emission factor [kgCO}_2\text{/kWh]} \times \text{Electricity imported [kWh]}$$

- Grid emission factor: The emission factor value for electricity consumption from grid is **0.79kgCO₂/kWh** according to Central Electricity Authority database.
- Consumption of the organisation:
Annual value according to survey = **191786.02 kWh/Year**
- Total carbon emission due to energy consumption from grid = **151510.95 kgCO₂**.

The CO₂ emission and there by impact on environment and climate can be reduced by implementing the energy saving recommendations and utilising more renewable energy sources.



12. ENERGY POLICY

It is recommended that the management shall take necessary steps to formulate and follow energy policy within the organization based on the international standard ISO 50001:2018 - Energy management systems - Requirements with guidance for use. The standard is applicable to any organization regardless of its type, size, complexity, geographical location, organizational culture or the products and services it provides. It provides guidelines pertaining to activities affecting energy performance that are managed and controlled by the organization. Based on this standard, the organization shall:

- Establish, document, implement and maintain and improve an EnMS (Energy Management System) in accordance with the requirements of this International Standard.
- Define and document the scope and the boundaries of its EnMS
- Determine how it will meet the requirements of this international standard in order to achieve continual improvement of its energy performance and of its EnMS.

Top management shall define the energy policy and ensure that

- It is appropriate to the nature and scale of the organisation's energy use and consumption and includes a commitment to continual improvement in energy performance.
- It includes a commitment to ensure the availability of information and of necessary resources to achieve objectives and targets.
- It includes a commitment to comply with applicable legal requirements and with other requirements to which the organisation subscribes which relate to its energy use, consumption, and efficiency.
- It provides the framework for setting and reviewing energy objectives and targets
- It supports the purchase of energy efficient products and services and design for energy performance improvement.
- It is documented and communicated at all levels within the organization and regularly reviewed, and updated as necessary.



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

13. RENEWABLE ENERGY INTEGRATION

Energy harvested from sun is one of the cleanest form of renewable energy available from nature. Installation of a solar plant of capacity 170kWp can generate approximately 20400 units per month, which can meet the monthly energy consumption (considering the energy consumption before pandemic) of the building.

| Particulars | Value | Unit |
|--|-------------|--------|
| Monthly energy demand | 20000 | kWh |
| Annual energy demand | 240000 | kWh |
| Proposed capacity of solar PV required to offset annual energy demand | 170 | kWp |
| As per the climatic condition at the location 1kWp generates 4 units/day. Hence total generation for 170kWp per day. | 680 | kWh |
| Annual energy yield | 244800 | kWh |
| Annual equivalent cost of energy generated @ Rs. 6.2 Rs/unit | 1517760 | INR |
| Investment @ 65,000/kWp | 1,10,50,000 | INR |
| Simple Pay Back Period | 88 | Months |

*Taking annual average of solar generation for a year, 4 kWh is the generation potential per day for a 1kWp plant



PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Thiruvananthapuram - 18

14. ANNEXURE 1: LIST OF INSTRUMENTS

List of Energy auditing instruments:

| | |
|---|---|
| Power quality analyser (Hioki PW-3360) |  |
| Lux meter |  |
| Current Clamps (1000A TRMS AC/DC CLAMP W/IFLEX) |  |
| Digital Sound Level Meter |  |
| Thermal Imager (Testo 865) |  |
| Handheld non-electrical tools (if required) | |
| PPE (if required) | |

15. ANNEXURE 2: LUX LEVEL TABLE

| SL.NO | DATE | LOCATION | AVERAGE LUX LEVEL (Including day light) |
|---------------------|------------|-------------------|--|
| GROUND FLOOR | | | |
| 1 | 12-02-2022 | Seminar Hall | 163.25 |
| 2 | 12-02-2022 | 111. Lecture Hall | 108.75 |
| 3 | 12-02-2022 | 110. Lecture Hall | 126.25 |
| 4 | 12-02-2022 | 108. Lecture Hall | 133.75 |
| 5 | 12-02-2022 | 105. Lecture Hall | 163.5 |
| 6 | 12-02-2022 | 102. Lecture Hall | 198 |
| 7 | 12-02-2022 | 101. Lecture Hall | 138.25 |
| FIRST FLOOR | | | |
| 8 | 12-02-2022 | 212. Lecture Hall | 111 |
| 9 | 12-02-2022 | 211. Lecture Hall | 103 |
| 10 | 12-02-2022 | 209. Lecture Hall | 127 |
| 11 | 12-02-2022 | 205. Lecture Hall | 125.25 |
| 12 | 12-02-2022 | 202. Lecture Hall | 182 |
| 13 | 12-02-2022 | 201. Lecture Hall | 105.5 |
| SECOND FLOOR | | | |
| 14 | 12-02-2022 | 316. Lecture Hall | 254.5 |
| 15 | 12-02-2022 | 315. Lecture Hall | 223.25 |
| 16 | 12-02-2022 | 314. Lecture Hall | 276.75 |
| 17 | 12-02-2022 | 313. Lecture Hall | 202.5 |
| 18 | 12-02-2022 | 312. Lecture Hall | 259 |
| 19 | 12-02-2022 | 311. Lecture Hall | 310.5 |
| 20 | 12-02-2022 | 310. Lecture Hall | 214.75 |
| 21 | 12-02-2022 | 309. Lecture Hall | 246.5 |
| 22 | 12-02-2022 | 308. Lecture Hall | 203 |
| 23 | 12-02-2022 | 305. Lecture Hall | 204 |
| 24 | 12-02-2022 | 304. Lecture Hall | 139.5 |
| 25 | 12-02-2022 | 302. Lecture Hall | 260 |
| 26 | 12-02-2022 | 301. Lecture Hall | 266.5 |
| THIRD FLOOR | | | |
| 27 | 12-02-2022 | SJ 19 | 409.5 |
| 26 | 12-02-2022 | SJ 16 | 374.25 |
| 27 | 12-02-2022 | SJ 14 | 308.5 |
| 28 | 12-02-2022 | SJ 5 | 392.5 |
| 29 | 12-02-2022 | SJ 4 | 376.75 |



16. ANNEXURE 3: LIST OF APPLIANCES


| Sl. No. | Name of the Equipment | Nos. |
|---------|-----------------------|------|
| 1 | LED TV | 3 |
| 2 | LED TV | 1 |
| 3 | Mixer Grinder | 1 |
| 4 | Water Purifier | 8 |
| 5 | Electric Kettle | 1 |
| 6 | Freezer | 1 |
| 7 | Refrigerator | 1 |
| 8 | Bottle Cooler | 1 |
| 9 | Motor – 5HP | 2 |

17. ANNEXURE 4: LIST OF LAB EQUIPMENTS

| SL.NO | LOCATION | LOAD | Wattage per appliance (kW) | No. of Appliances |
|-------|------------------------------------|---------------------------------------|----------------------------|-------------------|
| | LAB BUILDING | | | |
| 1 | Electrical & Electronics Engg. Lab | DC Motor | 3.5 | 1 |
| | | DC Motor - Generator Set | 4.2 | 1 |
| | | Generator | 3.7 | 1 |
| | | DC Motor - Generator Set | 5.2 | 1 |
| | | DC Motor | 3.7 | 1 |
| | | DC Motor - Alternator Set | 3.7 | 1 |
| | | Generator | 6 | 1 |
| | | Motor | 5.6 | 1 |
| | | Generator | 4 | 1 |
| | | 3 phase squirrel cage induction motor | 3.7 | 1 |
| | | 1 phase induction motor | 1.5 | 1 |
| | | 3 phase slip ring induction motor | 3.7 | 1 |
| | | 1 phase transformer | 2.4 | 1 |
| 2 | Fluid mechanics & machines lab | Motor 1 | 0.373 | 1 |
| | | Motor 2 | 0.746 | 1 |
| | | Motor 3 | 0.746 | 1 |
| | | Motor 4 | 0.746 | 1 |
| | | Motor 5 | 0.746 | 1 |
| | | Motor 6 | 5.5 | 1 |
| | | Motor 7 | 5.5 | 1 |
| | | Motor 8 | 0.373 | 1 |
| | | Motor 9 | 0.373 | 1 |




| SL.NO | LOCATION | LOAD | Wattage per appliance (kW) | No. of Appliances |
|-------|------------------------------------|--|----------------------------|-------------------|
| | | Motor 10 | 0.373 | 1 |
| 3 | Heat Engines Lab | Eddy current dynamometer | 80 | 1 |
| | | Centrifugal blower testing | 18.5 | 1 |
| | | Two stage air compressor testing | 5.595 | 1 |
| | | Rotary compressor test rig | 0.75 | 1 |
| 4 | Machine tool lab | Lathe machine | 2.2 | 18 |
| | | Universal milling machine | 3 | 7 |
| | | Universal milling machine - feed motor | 0.75 | 7 |
| | | Cylindrical Grinder | 2.238 | 1 |
| | | Cylindrical Grinder | 0.373 | 1 |
| | | Tool and cutter grinder | 0.2238 | 1 |
| | | Surface grinder | 1.492 | 1 |
| | | Shaping machine | 1.492 | 18 |
| | | Radial drilling machine | 1.5 | 1 |
| | | Hydraulic power saw | 0.75 | 1 |
| | | Slotting machine | 0.746 | 1 |
| 5 | Basic engineering workshop | Motor | 0.373 | 1 |
| | | Grinding machine | 0.7 | 1 |
| | | Drilling machine | 0.746 | 1 |
| | | Welding machine | 12 | 1 |
| 6 | 601. Metrology & Metallurgy lab | Furnace | 3.75 | 1 |
| | | Tool makers microscope | 0.25 | 1 |
| 7 | 622. Hardware lab | CRO | 0.04 | 11 |
| 8 | 623. Communication engineering lab | Power supply | | 11 |
| | | Function generator | 0.02 | 11 |
| 9 | 621. CIM lab | Co-ordinate measuring machine | | 1 |
| | | 3D Printer | 2.76 | 1 |
| | | Milling machine | 8.715 | 1 |
| | | Motor | 1.492 | 1 |
| | | CNC lathe | 1 | 1 |
| | | CNC Router | 2.231 | 1 |
| | | UPS | 4 | 1 |
| | | UPS | 2.4 | 1 |
| 10 | Strength of materials lab | Motor | 0.746 | 1 |
| | | Universal testing machine | 0.9698 | 1 |
| 11 | 604. CAD lab | UPS | 4 | 2 |
| | | UPS | 5.6 | 1 |
| 12 | Automobile lab | Valve refacer | 0.373 | 1 |
| | | Boring & Grinding machine | 0.373 | 3 |
| | | Brake drum | 0.75 | 1 |



(Handwritten signature)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

| SL.NO | LOCATION | LOAD | Wattage per appliance (kW) | No. of Appliances |
|-------|---|---------------------------------|----------------------------|-------------------|
| 13 | 808. Heat & mass transfer operations lab | Motor | 0.746 | 1 |
| | | Compressor | 3 | 1 |
| | | Venturimeter | 0.373 | 1 |
| | | Drag co-efficient apparatus | 0.373 | 1 |
| 14 | 807. Environmental lab | Incubator | 1.38 | 1 |
| | | Sieve | 0.5 | 1 |
| | | Shaking incubator | 0.5 | 1 |
| | | Motor | 0.249 | 1 |
| | | Mixing vessel | 0.66 | 1 |
| 15 | 806. Reaction engg. And process control lab | Isothermal batch reactor | 1 | 1 |
| | | Continuous stirred tank reactor | 1 | 1 |
| | | RTD studies INCSTU | 1 | 1 |
| | | Isothermal semi batch reactor | 1 | 1 |
| | | Water bath stirred | 0.5 | 2 |
| | | Cascade CSTR | 1 | 1 |
| | | Isothermal tubular reactor | 1 | 1 |
| | | Motor | 0.373 | 1 |
| 16 | 805. Downstream processing lab | Centrifuge | 0.11 | 1 |
| | | Flocculator | 0.1 | 1 |
| | | Motor | 0.1865 | 1 |
| | | Vaccum oven | 0.6 | 1 |
| | | Fluid bed dryer | 0.15 | 1 |
| | | Shaking incubator | 0.5 | 1 |
| | | BOD incubator | 1.38 | 1 |
| | | Hot air oven | 1.1 | 1 |
| 17 | 804. Software lab | UPS | 4 | 1 |
| 18 | 803. Biochemistry lab | LPG | | |
| | | Hot air oven | 1.1 | 1 |
| | | Cooling centrifuge | 0.11 | 1 |
| 19 | 802. Microbiology lab | Hot plate | 1.2 | 1 |
| | | Bacteriological Incubator | 0.345 | 1 |
| | | Centrifuge | 0.11 | 1 |
| 20 | Incubation Room | BOD incubator | 1.38 | 1 |
| 21 | 801. Biochemical Engg. Lab | Deep freezer | 0.92 | 1 |
| | | Orbital shaking incubator | 0.5 | 1 |
| | | Microwave oven | 1.2 | 1 |
| | | Centrifuge | 0.11 | 1 |
| | | Refridgerator - Non star | 0.25 | 1 |
| 22 | Incubation Room | Autoclave | 1.5 | 1 |
| | | Laminar air flow | 0.72 | 2 |



18. ANNEXURE 5: LIST OF BUILDINGS

- College Building
- Lab Building
- Lab Building 2
- Canteen Block
- Post Office Building
- CGPA Building

19. ANNEXURE 6: LIST OF MANUFACTURERS

| Item | Brands |
|--|---|
| LED Tube Light | Philips, Havells, Wipro, Syska |
| BEE Certified star rated Fan/ BLDC ceiling fan | Crompton Greaves, Havells, Luminous, Atomberg |
| Air Conditioner | Blue star, Voltas, Lloyd, LG, Carrier |
| Led Bulb | Havells, Syska, Philips, Wipro |

20. ANNEXURE 7: ROOM WISE LIST OF EQUIPMENTS

- College Building

| SL.NO | APPLIANCE | | | | | | | | | | | | | | | | |
|-------|--|-----------|--------------|----------|-----------|---------------------|--------------------------|-------------------------|---------------|----------------|------------------------|-------------------|-------------------------|--------------------|----------------|-------------------|---------------------|
| | | T12 (52W) | T12X2 (104W) | T8 (36W) | CFL (14W) | LED PANEL 2X2 (40W) | LED PANEL (15W) (SQUARE) | LED PANEL (15W) (ROUND) | LED BULB (9W) | LED TUBE (18W) | LED TUBE (18W) (SMALL) | EXHAUST FAN (60W) | EXHAUST FAN (40W) (40W) | PEDESTAL FAN (55W) | WALL FAN (50W) | CEILING FAN (60W) | nos.COMPUTER (120W) |
| | Name of Building/Room/Place/Area /Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| | GROUND FLOOR | | | | | | | | | | | | | | | | |
| 1 | Staff Room - CS | 2 | | | | | | | | 2 | | | | | | 3 | 1 |
| 2 | Toilet | | | | | | | | 4 | | | | | | | | |
| 3 | Corridor | 2 | | | | | | | | | | | | | | | |
| 4 | Ladies Toilet | 1 | | | | | | | 4 | | 4 | | | | | | |
| 5 | Staff Room - EC | | | | | | | | | 4 | | | | | | 4 | 1 |
| 6 | Toilet | 1 | | | | | | | | | | | | | | | |
| 7 | HOD - Applied Science | 2 | | | | | | | | | | | | | | 2 | |
| 8 | Toilet | | | | | | | | 1 | | 1 | | | | | | |



(Handwritten Signature)

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL.NO | APPLIANCE | | | | | | | | | | | | | | | | |
|--------------------|--|-----------|--------------|----------|-----------|---------------------|--------------------------|-------------------------|---------------|----------------|------------------------|-------------------|-------------------------|--------------------|----------------|-------------------|---------------------|
| | | T12 (52W) | T12X2 (104W) | T8 (36W) | CFL (14W) | LED PANEL 2X2 (40W) | LED PANEL (15W) (SQUARE) | LED PANEL (15W) (ROUND) | LED BULB (9W) | LED TUBE (18W) | LED TUBE (18W) (SMALL) | EXHAUST FAN (60W) | EXHAUST FAN (40W) (40W) | PEDESTAL FAN (55W) | WALL FAN (50W) | CEILING FAN (60W) | nos.COMPUTER (120W) |
| | Name of Building/Room/Place/Area /Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| 9 | 114. Lecture Hall | 1 | 4 | | | | | | | | | | | | | | 7 |
| 10 | 113. Exam Control Room | 2 | 7 | | | | | | | | | | | | | | 5 5 |
| 11 | 112. Seminar Hall | | | | | | 1 | | | | | | | | | | |
| 12 | Corridor | 1 | | | | | 9 | | | | | | | | | | |
| 13 | Central Library | 1 | 4 | | | | | | | | | | 1 | 2 | 1 | 2 | 2 |
| 14 | Central Library - First Floor | 2 | | | | | | | | | | | | | 2 | | 1 |
| 15 | 120. Digital Library | 3 | | | | | | | | | | | 2 | | | | |
| 16 | Technical Section | 2 | | | | | | | | | | | | | | | 2 |
| 17 | Staff Room | 1 | | | | | | | | | | | | | | | 1 |
| 18 | Toilet | | | | | | | 1 | | | 1 | | | | | | |
| 19 | Librarian | 1 | | | | | | | | | | | | | | | 1 |
| 20 | Toilet | | | | | | | 1 | | | 1 | | | | | | |
| 21 | Entrance | | 5 | | | | | | | | | | | | | | |
| 22 | Outdoor - Entrance | | | | | | | | 5 | | | | | | | | |
| 23 | 111. Lecture Hall | 3 | | | | | | | 2 | | | | | | | | 7 |
| 24 | 110. Lecture Hall | 3 | | | | | | | 2 | | | | | | | | 7 |
| 25 | Passage | 4 | | | | | | | | | | | | | | | |
| 26 | Skill Delivery Platform Kerala | | | | | 2 | | 2 | | | | | | | | | |
| 27 | 108. Lecture Hall | 3 | | | | | | | 2 | | | | | | | | 7 |
| 28 | 107. HOD - Dept. of EC | | | | | | | | 4 | | | | | | | | 2 1 |
| 29 | Toilet | | | | | | | 1 | | 1 | 1 | | | | | | |
| 30 | 106. Staff Room - EC | 1 | | | | | | | 4 | | | | | 1 | 4 | | 1 |
| 31 | Toilet | 1 | | | | | | 1 | | | | | | | | | |
| 32 | 105. Lecture Hall | 5 | | | | | | | | | | | | | | | 7 |
| 33 | 104. Seminar Hall | | | | | | 8 | | | | | | | 8 | | | |
| 34 | 103. Gents Toilet | 2 | | | | | | 4 | | | 1 | | | | | | |
| 35 | 102. Lecture Hall | 1 | | | | | | | 4 | | | | | | | | 7 |
| 36 | 101. Lecture Hall | 2 | | | | | | | 2 | | | | | | | | 7 |
| FIRST FLOOR | | | | | | | | | | | | | | | | | |
| 37 | Stair | 4 | | | | | | | | | | | | | | | |
| 38 | Ladies Toilet | 2 | | | | | | | | | 3 | | | | | | |
| 39 | 220. Dept. Library EC | 2 | | | | | | | | | | | | | | | 2 |
| 40 | 219. Staff Room ME | 2 | | | | | | | | | | | | | | | 7 1 |
| 41 | 218. Staff Room ME | 3 | | | | | | | | | | | | | | | 6 |
| 42 | Toilet | | | | | | | | | | 1 | | | | | | |



67
PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL.N O | APPLIANCE | T12 (52W) | T12X2 (104W) | T8 (36W) | CFL (14W) | LED PANEL 2X2 (40W) | LED PANEL (15W) (SQUARE) | LED PANEL (15W) (ROUND) | LED BULB (9W) | LED TUBE (18W) | LED TUBE (18W) (SMALL) | EXHAUST FAN (60W) | EXHAUST FAN (40W) (40W) | PEDESTAL FAN (55W) | WALL FAN (50W) | CEILING FAN (60W) | nos. COMPUTER (120W) | |
|--|--|-----------|--------------|----------|-----------|---------------------|--------------------------|-------------------------|---------------|----------------|------------------------|-------------------|-------------------------|--------------------|----------------|-------------------|----------------------|------|
| | | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| Name of Building/Room/Place/Area /Location | | | | | | | | | | | | | | | | | | |
| 43 | Passage | 3 | 3 | | | | | | | | | | | | | | | |
| 44 | 217. HOD Dept. of Biotechnology & Biochemical Eng. | 1 | | | | | | | | 2 | | | | | | 2 | 1 | |
| 45 | Toilet | | | | | | | | 1 | | 1 | 1 | | | | | | |
| 46 | 214. Office | 4 | | | | | | | | | | | | | | 4 | 3 | |
| 47 | Store Room | 2 | | | | | | | | | | | | | | 1 | | |
| 48 | Toilet | 1 | | | | | | | | | | 1 | | | | | | |
| 49 | Office | 2 | 5 | | | | | | | | | | | | | | 8 | 6 |
| 50 | Administrative Officer | 2 | | | | | | | | | | | | | | | 1 | 1 |
| 51 | 213. Principal Room - Waiting Area | 7 | | | | | | | | | | | | | | | 3 | 1 |
| 52 | Principal Room | | 9 | | | | | | | | | | | | 3 | | | 1 |
| 53 | Passage | 1 | | | | | | | | | | | | | 1 | | | |
| 54 | Room | | 1 | | | | | | | | | | | | 1 | | | |
| 55 | Toilet | 1 | | | | | | | 1 | | | 1 | | | | | | |
| 56 | 212. Lecture Hall | 1 | 4 | | | | | | | | | | | | | | 7 | |
| 57 | 211. Lecture Hall | | 4 | | | | | | | | | | | | | | 7 | |
| 58 | 210. Seminar Hall ME | | | | | | 1 | | | | | | | | 6 | | | |
| 59 | 209. Lecture Hall | 1 | 4 | | | | 5 | | | | | | | | | | 7 | |
| 60 | 208. HOD - Mechanical Engg. | 2 | | | | | | | | | | | | | | 2 | 1 | |
| 61 | Toilet | 1 | | | | | | | 1 | | | 1 | | | | | | |
| 62 | 207. Staff Room ME | 4 | | | | | | | | | | | | | 1 | 4 | 2 | |
| 63 | Toilet | 1 | | | | | | | 1 | | | 1 | | | | | | |
| 64 | Dept. Library ME | 2 | | | | | | | | | | | | | | | 2 | |
| 65 | 205. Lecture Hall | 1 | 4 | | | | | | | | | | | | | | 7 | |
| 66 | 204. Dept. Library BT | 2 | | | | | | | | | | | | | | | 2 | |
| 67 | 203. Gents Toilet | 2 | | | | | | | 4 | | | 4 | | | | | | |
| 68 | 202. Lecture Hall | 1 | 4 | | | | | | | | | | | | | | 7 | |
| 69 | 201. Lecture Hall | | 3 | | | | | | | | | | | | | | 7 | |
| SECOND FLOOR | | | | | | | | | | | | | | | | | | |
| 70 | Stair | 4 | | | | | | | | | | | | | | | | |
| 71 | 320. Toilet - Ladies | 2 | | | | | | | 4 | | | 4 | | | | | | |
| 72 | Passage | 1 | 2 | | | | | | | | | | | | | | | |
| 73 | Seminar Hall - BT | | | | | | | | | | | | | | | | | |
| 74 | 318. Staff Room - BT | 4 | | | | | | | | | | | | | | | 4 | |



Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL.NO | APPLIANCE | | | | | | | | | | | | | | | | |
|--------------------|--|-----------|--------------|----------|-----------|---------------------|--------------------------|-------------------------|---------------|----------------|------------------------|-------------------|-------------------------|--------------------|----------------|-------------------|---------------------|
| | | T12 (52W) | T12X2 (104W) | T8 (36W) | CFL (14W) | LED PANEL 2X2 (40W) | LED PANEL (15W) (SQUARE) | LED PANEL (15W) (ROUND) | LED BULB (9W) | LED TUBE (18W) | LED TUBE (18W) (SMALL) | EXHAUST FAN (60W) | EXHAUST FAN (40W) (40W) | PEDESTAL FAN (55W) | WALL FAN (50W) | CEILING FAN (60W) | nos.COMPUTER (120W) |
| | Name of Building/Room/Place/Area /Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| 75 | Toilet | 1 | | | | | | 1 | | | 1 | | | | | | |
| 76 | 317. Staff Room - Electrical | 2 | | | | | | | 1 | | | | | 1 | 2 | 1 | |
| 77 | Toilet | 1 | | | | | | 1 | | | 1 | | | | | | |
| 78 | 316. Lecture Hall | 1 | 4 | | | | | | | | | | | | 5 | | |
| 79 | 315. Lecture Hall | 5 | | 1 | | | | | | | | | | | 7 | | |
| 80 | 314. Lecture Hall | 5 | | | | | | | | | | | | | 7 | | |
| 81 | 313. Lecture Hall | 5 | | | | | | | | | | | | | 7 | | |
| 82 | 312. Lecture Hall | 5 | | | | | | | | | | | | | 5 | | |
| 83 | 311. Lecture Hall | 5 | | | | | | | | | | | | | 7 | | |
| 84 | 310. Lecture Hall | 5 | | | | | | | | | | | | | 7 | | |
| 85 | 309. Lecture Hall | 5 | | | | | | | | | | | | | 7 | | |
| 86 | 308. Lecture Hall | 1 | 4 | | | | | | | | | | | | 7 | | |
| 87 | 307. HOD Dept. of Computer Science & Engg. | | | | | | | | 2 | | | | | | 2 | 1 | |
| 88 | Toilet | 1 | | | | | | 1 | | | 1 | | | | | | |
| 89 | 306. Staff Room - Civil | 2 | | | | | | | | | | | | | 2 | | |
| 90 | Toilet | 1 | | | | | | 1 | | | 1 | | | | | | |
| 91 | 305. Lecture Hall | 1 | 4 | | | | | | | | | | | | 7 | | |
| 92 | 304. Lecture Hall | 1 | 4 | | | | | | | | | | | | 7 | | |
| 93 | Gents Toilet | 2 | | | | | | 4 | | | 1 | | | | | | |
| 94 | 302. Lecture Hall | | 4 | | | | | | | | | | | | 7 | | |
| 95 | 301. Lecture Hall | 1 | 4 | | | | | | | | | | | | 7 | | |
| THIRD FLOOR | | | | | | | | | | | | | | | | | |
| 96 | Toilet | | | | | | | 7 | | 1 | | 5 | | | | | |
| 97 | Passage | | | | | | | | 2 | | | | | | | | |
| 98 | SJ 19 | | | | | | | | | | | | | | | 4 | |
| 99 | SJ 18 | | | | | | | 1 | | | | | | | | 4 | |
| 100 | Toilet | | | | | | | 2 | | | | | | | | | |
| 100 | Toilet | | | | | | | 1 | | 1 | | 1 | | | | | |
| 101 | SJ 17 | | | | | | | 6 | | | | | | | 2 | 1 | |
| 102 | SJ 16 | | | | | | | 1 | | | | | | | 6 | | |
| 103 | SJ 15 - Microwave Engg. Lab | | | | | | | 2 | | | | | | | 6 | | |
| 104 | SJ 14 | | | | | | | 1 | | | | | | | 4 | | |
| 105 | SJ 13 | | | | | | | 2 | | | | | | | 4 | | |



Principal
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

| SL.NO | APPLIANCE | | | | | | | | | | | | | | | | |
|--|--------------|-----------|--------------|----------|-----------|---------------------|--------------------------|-------------------------|---------------|----------------|------------------------|-------------------|-------------------------|--------------------|----------------|-------------------|---------------------|
| | | T12 (52W) | T12X2 (104W) | T8 (36W) | CFL (14W) | LED PANEL 2X2 (40W) | LED PANEL (15W) (SQUARE) | LED PANEL (15W) (ROUND) | LED BULB (9W) | LED TUBE (18W) | LED TUBE (18W) (SMALL) | EXHAUST FAN (60W) | EXHAUST FAN (40W) (40W) | PEDESTAL FAN (55W) | WALL FAN (50W) | CEILING FAN (60W) | nos.COMPUTER (120W) |
| Name of Building/Room/Place/Area /Location | | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| 106 | SJ 12 | | | | | | | 1 | | | | | | | | | 5 |
| 107 | SJ 11, 10 | | | | | | | 2 | | | | | | | | | 8 |
| 108 | SJ 9 | | | | | | | 1 | | | | | | | | | 6 |
| 109 | SJ 8 | | | | | | | 2 | | | | | | | | | 4 |
| 110 | SJ 7 | | | | | | | 1 | | | | | | | | | 4 |
| 111 | Toilet | | | | | | | 2 | | 1 | | 1 | | | | | |
| 112 | SJ 6 | | | | | | | 6 | | | | | | | | | 2 |
| 113 | Toilet | | | | | | | 1 | | 1 | | 1 | | | | | |
| 114 | SJ 5 | | | | | | | 1 | | | | | | | | | 4 |
| 115 | SJ 4 | | | | | | | 2 | | | | | | | | | 4 |
| 116 | Gents Toilet | | | | | | | 8 | | 1 | | 4 | | | | | |
| 117 | SJ 2 | | | | | | | 2 | | | | | | | | | 8 |

| SL. NO | APPLIANCE | | | | | | | | | | | | | | | | | | |
|--|-----------------------|---------------|---------|------------------|------------------|-----|----------------|--------|-------|------|---------|-----|--------------|--------------|--------------|----------------------|------|------|------|
| | | LAPTOP (120W) | PRINTER | PROJECTOR (500W) | NON STAR AC 1.5T | | NON STAR AC 1T | | AC 2T | | AC 1.5T | | LED TV (50W) | LED TV (80W) | XEROX (920W) | WATER PURIFIER (50W) | | | |
| Name of Building/Room/Place /Area/Location | | nos. | nos. | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | nos. | nos. | nos. |
| GROUND FLOOR | | | | | | | | | | | | | | | | | | | |
| 1 | Staff Room - CS | | | | | | | | | | | | | | | | | | |
| 2 | Toilet | | | | | | | | | | | | | | | | | | |
| 3 | Corridor | | | | | | | | | | | | | | | | | | 1 |
| 4 | Ladies Toilet | | | | | | | | | | | | | | | | | | |
| 5 | Staff Room - EC | 6 | | | | | | | | | | | | | | | | | |
| 6 | Toilet | | | | | | | | | | | | | | | | | | |
| 7 | HOD - Applied Science | | | | | | | | | | | | | | | | | | |
| 8 | Toilet | | | | | | | | | | | | | | | | | | |
| 9 | 114. Lecture Hall | | | 1 | | | | | | | | | | | | | | | |



(Signature)
PRINCIPAL
 Sree Chitra Thirunal
 State College of Engineering
 Thiruvananthapuram - 18

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | LAPTOP (120W) | | PRINTER | | PROJECTOR (500W) | | NON STAR AC 1.5T | | | NON STAR AC 1T | | | AC 2T | | | AC 1.5T | | | LED TV (50W) | | LED TV (80W) | | XEROX (920W) | | WATER PURIFIER (50W) | |
|--------------------|--------------------------------|---------------|------|---------|--------|------------------|------|------------------|-----|------|----------------|-----|------|--------|-----|------|---------|-----|------|--------------|------|--------------|------|--------------|------|----------------------|--|
| | | nos. | nos. | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | |
| 10 | 113. Exam Control Room | | 1 | | | | | | | | | | | | | | | | | 2 | | | | | | | |
| 11 | 112. Seminar Hall | | | | | | | | | | | 6 | | | | | | | | | | | | | | | |
| 12 | Corridor | | | | | | | | | | | | | | | | | | | | | | | | | 1 | |
| 13 | Central Library | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 14 | Central Library - First Floor | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 15 | 120. Digital Library | | | | | | | | | | | | | 3 | 2 | 1 | | | | | | | | | | | |
| 16 | Technical Section | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 17 | Staff Room | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 18 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 19 | Librarian | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 20 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 21 | Entrance | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 22 | Outdoor - Entrance | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 23 | 111. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | |
| 24 | 110. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | |
| 25 | Passage | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 26 | Skill Delivery Platform Kerala | 5 | 9 | | | | | | | | | | | | | | 4 | | | | | 1 | | | | | |
| 27 | 108. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | |
| 28 | 107. HOD - Dept. of EC | | 1 | | | | | 1 | | | | | | | | | | | | | | | | | | | |
| 29 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 30 | 106. Staff Room - EC | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 31 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 32 | 105. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | |
| 33 | 104. Seminar Hall | | | 1 | | | | | | | | | | | | | 1 | | | | | | | | | | |
| 34 | 103. Gents Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 35 | 102. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | |
| 36 | 101. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | |
| FIRST FLOOR | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 37 | Stair | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 38 | Ladies Toilet | | | | | | | | | | | | | | | | | | | | | | | | | 1 | |
| 39 | 220. Dept. Library EC | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 40 | 219. Staff Room ME | | 1 | | | | | | | | | | | | | | | | | | | | | | | | |
| 41 | 218. Staff Room ME | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 42 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 43 | Passage | | | | | | | | | | | | | | | | | | | | | | | | | 1 | |



Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | LAPTOP (120W) | | | PRINTER | | | PROJECTOR (500W) | | | NON STAR AC 1.5T | | | NON STAR AC 1T | | | AC 2T | | | AC 1.5T | | | LED TV (50W) | | | LED TV (80W) | | | XEROX (920W) | | | WATER PURIFIER (50W) | | | | | | | | | | | | | | | | | | |
|---------------------|--|---------------|------|------|---------|-----|------|------------------|-----|------|------------------|-----|------|----------------|-----|------|--------|-----|------|---------|-----|------|--------------|-----|------|--------------|-----|------|--------------|-----|------|----------------------|-----|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|--|
| | | nos. | nos. | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | | | | | | | | | | | | | | | | | |
| 44 | 217. HOD Dept. of Biotechnology & Biochemical Eng. | | 1 | | | | | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 45 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 46 | 214. Office | | 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 47 | Store Room | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 48 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 49 | Office | | 5 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 50 | Administrative Officer | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 51 | 213. Principal Room - Waiting Area | | 2 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 52 | Principal Room | | 1 | 1 | | | | | | | | | | | | | 3 | 3 | | | | | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | |
| 53 | Passage | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 54 | Room | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 55 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 56 | 212. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 57 | 211. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 58 | 210. Seminar Hall ME | | | 1 | | | | | | | | | | | | | | | | | | | | | | 3 | 3 | | | | | | | | | | | | | | | | | | | | | | | |
| 59 | 209. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 60 | 208. HOD - Mechanical Engg. | | 1 | | | | | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 61 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 62 | 207. Staff Room ME | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 63 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 64 | Dept. Library ME | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 65 | 205. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 66 | 204. Dept. Library BT | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 67 | 203. Gents Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 68 | 202. Lecture Hall | | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 69 | 201. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| SECOND FLOOR | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 70 | Stair | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 71 | 320. Toilet - Ladies | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 72 | Passage | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 73 | Seminar Hall - BT | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 74 | 318. Staff Room - BT | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 75 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 76 | 317. Staff Room - Electrical | | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 77 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |



[Signature]
PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | LAPTOP (120W) | | PRINTER | PROJECTOR (500W) | | | NON STAR AC 1.5T | | | NON STAR AC 1T | | | AC 2T | | | AC 1.5T | | | LED TV (50W) | | LED TV (80W) | | XEROX (920W) | | WATER PURIFIER (50W) | |
|--------------------|--|---------------|------|---------|------------------|-----|------|------------------|-----|------|----------------|-----|------|--------|-----|------|---------|-----|------|--------------|------|--------------|------|--------------|------|----------------------|---|
| | | nos. | nos. | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | |
| 78 | 316. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 79 | 315. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 80 | 314. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 81 | 313. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 82 | 312. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 83 | 311. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 84 | 310. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 85 | 309. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 86 | 308. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 87 | 307. HOD Dept. of Computer Science & Engg. | 1 | | | | | | | | | 1 | | | | | | | | | | | | | | | | |
| 88 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 89 | 306. Staff Room - Civil | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 90 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 91 | 305. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 92 | 304. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 93 | Gents Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 94 | 302. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 95 | 301. Lecture Hall | | | | | | | | | | | | | | | | | | | | | | | | | | |
| THIRD FLOOR | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 96 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 97 | Passage | | | | | | | | | | | | | | | | | | | | | | | | | | 1 |
| 98 | SJ 19 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 99 | SJ 18 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 100 | Toilet | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 101 | SJ 17 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 102 | SJ 16 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 103 | SJ 15 - Microwave Engg. Lab | | | | | | | | | | | | | | | | 4 | 2 | 2 | | | | | | | | |
| 104 | SJ 14 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 105 | SJ 13 | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 106 | SJ 12 | | | | | | | | | | | | | | | | | | | | | | | | | | |



(Handwritten signature in green ink)

PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 1*

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | LAPTOP (120W) | | PRINTER | PROJECTOR (500W) | | NON STAR AC 1.5T | | NON STAR AC 1T | | AC 2T | | AC 1.5T | | LED TV (50W) | LED TV (80W) | XEROX (920W) | WATER PURIFIER (50W) | |
|--------|--------------|---------------|------|---------|------------------|-----|------------------|--------|----------------|------|--------|-----|---------|--------|--------------|--------------|--------------|----------------------|------|
| | | nos. | nos. | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | ton | nos. | nos. | nos. | nos. |
| 107 | SJ 11, 10 | | | | | | | | | | | | 4 | 1 5 | 2 | | | | |
| 108 | SJ 9 | | | 1 | | | | | | | | | | | | | | | |
| 109 | SJ 8 | | | | | | | | | | | | | | | | | | |
| 110 | SJ 7 | | | | | | | | | | | | | | | | | | |
| 111 | Toilet | | | | | | | | | | | | | | | | | | |
| 112 | SJ 6 | | | | | | | | | | | | | | | | | | |
| 113 | Toilet | | | | | | | | | | | | | | | | | | |
| 114 | SJ 5 | | | | | | | | | | | | | | | | | | |
| 115 | SJ 4 | | | | | | | | | | | | | | | | | | |
| 116 | Gents Toilet | | | | | | | | | | | | | | | | | | |
| 117 | SJ 2 | | | | | | | | | | | | | | | | | | |



(Handwritten signature in green ink)

• Lab Building

| SL.N O | APPLIANCE | | | | | | | | | | | | | | | |
|-----------|---|-----------|--------------|--------|----------------|---------|-----------------|---------------|----------------|-------------------|-------------------|---------------------|---------------------|----------------|--------------|-------------------|
| | | T12 (52W) | T12x2 (104W) | T8 18W | LED SPOT (12W) | CFL 70W | LED PANEL (15W) | LED BULB (9W) | LED TUBE (18W) | EXHAUST FAN (60W) | PEDESTALFAN (55W) | PEDESTAL FAN (200W) | PEDESTAL FAN (180W) | WALL FAN (50W) | WALL FAN 80W | CEILING FAN (60W) |
| | Name of Building/Room/Place/Area/Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| | LAB BUILDING | | | | | | | | | | | | | | | |
| 1 | Electrical Engg. Workshop | | | | | | | 1 | 3 | | | | | | | 3 |
| 2 | Electrical & Electronics Lab | | 7 | | | | | | | | | | | 3 | | 3 |
| 3 | Lab-in-charge | | | | | | | | 2 | | | | 1 | | | |
| 4 | Fluid Mechanics & Machines Lab | | 6 | | | | | | 1 | | | | | | | 5 |
| 5 | FM lab room | | | | | | | | 4 | | | | | | | 2 |
| 6 | Toilet | | | | | | | 1 | | | | | | | | |
| 7 | Staff Room | | | | | | | | 1 | | | | | | | |
| 8 | Heat Engines Lab | | | | | | | | 2 | | | | | | | 2 |
| 9 | Lab area | 1 | 1 | | | | | | 6 | | | | | | | |
| 10 | Machine tool lab | 19 | 6 | | | | | | | | 1 | 2 | | | | 3 |
| 11 | Staff Room 2 | 4 | | | | | | | | | | | | | | 3 |
| 12 | Staff Room 1 | 4 | | | | | | | | | | | | | | 4 |
| 13 | Toilet | 1 | | | | | | | | | | | | | | |
| 14 | Basic engineering workshop | | 16 | | | | | | | | 3 | | | | | 12 |
| 15 | Toilet | 2 | | | | | | | | 2 | | | | | | |
| 16 | Toilet - Ladies | | | | | | | | | | | | | | | 1 |
| 17 | Soil testing lab | | 1 | | | | | | | | | | | | | 1 |
| 18 | Engineering chemistry lab | 4 | | | | | | | | | 2 | | | | | 6 |
| 19 | Store | 1 | 1 | | | | | | | | | | | | | 1 |
| 20 | Staff Room | 1 | | | | | | | | | | | | 2 | | |
| 21 | 601. Metrology & Metallurgy lab | 4 | 5 | | | | | | | | | | | | | |
| 22 | 622. Hardware lab | 11 | | | | | | | 4 | | | | 1 | | | 6 |
| 23 | 623. Communication engineering lab | | | | 12 | | | | 2 | | | | 7 | | | |
| 24 | 621. CIM lab | 7 | | | | | | | | | | | | | | |
| 25 | Drawing hall | | 9 | | | 6 | | | | | | | | | | 9 |
| 26 | Strength of materials lab | 1 | 3 | | | | | | | | | | | | | |
| 27 | 604. CAD lab | 2 | 10 | | | | | | | | | | | | | |
| 28 | 603. Research Lab | | | | | | | | 5 | | | | 1 | | | |
| 29 | Store | | | | | | | | 1 | | | | | | | |
| 30 | Research Lab Entrance | | | | | | | | 2 | | | | 2 | | | |
| 31 | 605. Workshop Superintendent | | | | | | | | 3 | | | | | | | 2 |
| 32 | Automobile lab | 3 | 2 | | | | | | | | | | | | | 1 |



Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL.NO | APPLIANCE | | | | | | | | | | | | | | | |
|-------|---|-----------|--------------|--------|----------------|---------|-----------------|---------------|----------------|-------------------|-------------------|---------------------|---------------------|----------------|--------------|-------------------|
| | | T12 (52W) | T12x2 (104W) | T8 18W | LED SPOT (12W) | CFL 70W | LED PANEL (15W) | LED BULB (9W) | LED TUBE (18W) | EXHAUST FAN (60W) | PEDESTALFAN (55W) | PEDESTAL FAN (200W) | PEDESTAL FAN (180W) | WALL FAN (50W) | WALL FAN 80W | CEILING FAN (60W) |
| | Name of Building/Room/Place/Area/Location | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. |
| 33 | Room | 1 | | | | | | | | | | | | | | |
| 34 | Vehicle system lab | 11 | 8 | | | | | | | | | | | | | 8 |
| 35 | 609. Vehicle testing lab | 5 | | | | | | | | | | | | | | 1 |
| 36 | 808. Heat & mass transfer operations lab | | | | | | | 7 | | | | | 3 | | | 3 |
| 37 | 807. Environmental lab | 5 | 2 | | | | | | | | | | | | | 5 |
| 38 | 806. Reaction engg. And process control lab | | 8 | | | | | | 1 | | | | | | | 6 |
| 39 | Room | 2 | 1 | | | | | | | | | | | | | 2 |
| 40 | Room 2 | 1 | | | | | | | | | | | | | | |
| 41 | Store | 1 | | | | | | | | | | | | | | |
| 42 | 805. Downstream processing lab | 9 | | | | | | | | | | | | | | 5 |
| 43 | Room | | 2 | | | | | | | | | | 2 | | | |
| 44 | 804. Software lab | | | | | | 12 | | | 1 | | | 4 | | | |
| 45 | 803. Biochemistry lab | 8 | | | | | | | | | | | 4 | | | |
| 46 | 802. Microbiology lab | 4 | 2 | | | | | 4 | 1 | | | | | | | |
| 47 | Incubation Room | 1 | 1 | 8 | | | | | | | | | | | | |
| 48 | Store | 1 | | | | | | | | | | | | | | |
| 49 | Passage | 2 | | | | | | | | | | | | | | |
| 50 | 801. Biochemical Engg. Lab | 4 | 3 | | | | | | | 1 | | | | | | 7 |
| 51 | Store | 1 | | | | | | | | | | | | | | |
| 52 | Incubation Room | 2 | | | | | | | | | | | | | | 1 |
| 53 | Dark room | 1 | | | | | | | | | | | | | | |

| SL. NO | APPLIANCE | | | | | | | | | | | | | | | | | | |
|--------|---|-----------------|---------------|---------|------------------|-----------|------------------|-----|-------|--------|---------|------|-------------------------|----------------------|----------------------|--------|------|------|--|
| | | COMPUTER (120W) | LAPTOP (120W) | PRINTER | PROJECTOR (500W) | WINDOW AC | NON STAR AC 1.5T | | AC 2T | | AC 1.5T | | ELECTRIC KETTLE (1500W) | REFRIDGERATOR (136W) | WATER PURIFIER (50W) | | | | |
| | Name of Building/Room/Place/Area/Location | nos. | nos. | nos. | nos. | rating | nos. | ton | nos. | rating | ton | nos. | rating | ton | nos. | rating | nos. | nos. | |
| | LAB BUILDING | | | | | | | | | | | | | | | | | | |



(Handwritten Signature)
PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Trivandrum - 18

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | COMPUTER (120W) | | LAPTOP (120W) | | PRINTER | | PROJECTOR (500W) | | WINDOW AC | | NON STAR AC 1.5T | | AC 2T | | AC 1.5T | | ELECTRIC KETTLE (1500W) | | REFRIDGERATOR (136W) | | WATER PURIFIER (50W) | |
|--------|------------------------------------|-----------------|------|---------------|------|---------|------|------------------|------|-----------|-----|------------------|--------|-------|------|---------|--------|-------------------------|--------|----------------------|------|----------------------|--|
| | | nos. | nos. | nos. | nos. | rating | nos. | ton | nos. | rating | ton | nos. | rating | ton | nos. | nos. | rating | nos. | rating | nos. | nos. | | |
| 1 | Electrical Engg. Workshop | | | | | | | | | | | | | | | | | | | | | | |
| 2 | Electrical & Electronics Lab | | | | | | | | | | | | | | | | | | | | | | |
| 3 | Lab-in-charge | | | | | | | | | | | | | | | | | | | | | | |
| 4 | Fluid Mechanics & Machines Lab | | | | | | | | | | | | | | | | | | | | | | |
| 5 | FM lab room | | 1 | | | | | | | | | | | | | | | | | | | | |
| 6 | Toilet | | | | | | | | | | | | | | | | | | | | | | |
| 7 | Staff Room | | | | | | | | | | | | | | | | | | | | | | |
| 8 | Heat Engines Lab | | | | | | | | | | | | | | | | | | | | | | |
| 9 | Lab area | | | | | | | | | | | | | | | | | | | | | | |
| 10 | Machine tool lab | | | | | | | | | | | | | | | | | | | | | | |
| 11 | Staff Room 2 | | | | | | | | | | | | | | | | | | | | | | |
| 12 | Staff Room 1 | | | | | | | | | | | | | | | | | | | | | | |
| 13 | Toilet | | | | | | | | | | | | | | | | | | | | | | |
| 14 | Basic engineering workshop | | | | | | | | | | | | | | | | | | | | | | |
| 15 | Toilet | | | | | | | | | | | | | | | | | | | | | | |
| 16 | Toilet - Ladies | | | | | | | | | | | | | | | | | | | | | | |
| 17 | Soil testing lab | | | | | | | | | | | | | | | | | | | | | | |
| 18 | Engineering chemistry lab | | | | | | | | | | | | | | | | | | | | | | |
| 19 | Store | 1 | | 1 | | | | | | | | | | | | | | | 1 | | | | |
| 20 | Staff Room | | | | | | | | | | | | | | | | | | | | | | |
| 21 | 601. Metrology & Metallurgy lab | | | | | | | | | 3 | 2 | 2 | | | | | | | | | | | |
| 22 | 622. Hardware lab | 1 2 | | | | | | | | | | | | | | | | | | | | | |
| 23 | 623. Communication engineering lab | | | | | | | | | 3 | 2 | 2 | | | | | | | | | | | |
| 24 | 621. CIM lab | | | | | | | | | | | | | | | | | | | | | | |
| 25 | Drawing hall | | | | | | | | | | | | | | | | | | | | | | |
| 26 | Strength of materials lab | | | | | | | | | | | | | | | | | | | | | | |
| 27 | 604. CAD lab | 4 0 | | | 1 | | | | | | 1 | | | | | | 1 5 | 1 | | | | | |
| 28 | 603. Research Lab | | | | | | | | | | | | | | | | 3 5 | 1 | | | | | |
| 29 | Store | | | | | | | | | | | | | | | | | | | | | | |



(Handwritten Signature)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | COMPUTER (120W) | | LAPTOP (120W) | | PRINTER | | PROJECTOR (500W) | | WINDOW AC | | NON STAR AC 1.5T | | AC 2T | | AC 1.5T | | ELECTRIC KETTLE (1500W) | | REFRIDGERATOR (136W) | | WATER PURIFIER (50W) | |
|--------|---|-----------------|------|---------------|------|---------|------|------------------|------|-----------|-----|------------------|--------|-------|------|---------|--------|-------------------------|------|----------------------|---|----------------------|---|
| | | nos. | nos. | nos. | nos. | rating | nos. | ton | nos. | rating | ton | nos. | rating | ton | nos. | nos. | rating | nos. | nos. | nos. | | | |
| 30 | Research Lab Entrance | | | | | | | | | | | | | | | | | | | | | | |
| 31 | 605. Workshop Superintendent | 1 | | 1 | | | | | | | | | | | | | | | | | | | |
| 32 | Automobile lab | | | | | | | | | | | | | | | | | | | | | | |
| 33 | Room | | | | | | | | | | | | | | | | | | | | | | |
| 34 | Vehicle system lab | | | | | | | | | | | | | | | | | | | | | | 1 |
| 35 | 609. Vehicle testing lab | | | | | | | | | | | | | | | | | | | | | | |
| 36 | 808. Heat & mass transfer operations lab | | | | | | | | | | | | | | | | | | | | | | |
| 37 | 807. Environmental lab | | | | | | | | | 2 | | | | | | | | | | | | | |
| 38 | 806. Reaction engg. And process control lab | | | | | | | | | | | | | | | | | | | | | | |
| 39 | Room | 2 | | 1 | | | | | | | | | | | | | | | | | | | |
| 40 | Room 2 | | | | | | | | | | | | | | | | | | | | | | |
| 41 | Store | | | | | | | | | | | | | | | | | | | | | | |
| 42 | 805. Downstream processing lab | 1 | | 1 | | | | 2 | | | | | | | | | | | | | | | |
| 43 | Room | | | | | | | | | | | | | | | | | | | | | | |
| 44 | 804. Software lab | 1 4 | | 1 | | | | 1 | | | | | | | | | | | | | | | |
| 45 | 803. Biochemistry lab | | | | | | | | | | | | | | | | | | | 5 | 1 | | |
| 46 | 802. Microbiology lab | | | | | | | | | | | | | | | | | | | | | | |
| 47 | Incubation Room | | | | | | | | | | | | | | | | | | | | | | |
| 48 | Store | | | | | | | | | | | | | | | | | | | | | | |
| 49 | Passage | | | | | | | | | | | | | | | | | | | | | | |
| 50 | 801. Biochemical Engg. Lab | | | | | | | | | 2 | | | | | | | | | | | | | |
| 51 | Store | | | | | | | | | | | | | | | | | | | | | | |
| 52 | Incubation Room | | | | | | | | | 1 | | | | | | | | | | | | | |
| 53 | Dark room | | | | | | | | | | | | | | | | | | | | | | |

- Lab Building 2




PRINCIPAL
 Sree Chitra Thirunal
 College of Engineering
 Thiruvananthapuram - 695 011

| SL.NO | APPLIANCE | T12 (52W) | | LED PANEL (15W) | | LED TUBE (18W) | | WALL FAN (50W) | | CEILING FAN (60W) | | COMPUTER (120W) | | PROJECTOR (500W) | | NON STAR AC 2T | | AC 2T | | AC 1.5T | | |
|-------|--|-----------|------|-----------------|------|----------------|------|----------------|------|-------------------|------|-----------------|-----|------------------|--------|----------------|------|-------|--|---------|-----|---|
| | | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | ton | nos. | rating | ton | nos. | rating | ton | nos. | | | | | |
| | Name of Building/Room/Place/Area/Location | | | | | | | | | | | | | | | | | | | | | |
| | LAB BUILDING 2 | | | | | | | | | | | | | | | | | | | | | |
| | GROUND FLOOR | | | | | | | | | | | | | | | | | | | | | |
| 1 | 701. Embedded systems lab (PG) - Server room | 3 | | | | | | | | 1 | | | | | | | | | | 3 | 1.5 | 1 |
| 2 | Lab area | | 8 | | | 2 | | | | 14 | 1 | | | | | | | | | 3 | 1.5 | 1 |
| 3 | 702. Embedded systems lab (UG) | | 12 | 3 | 4 | | | | | | 1 | 2 | 1 | 3 | 2 | 1 | | | | | | |
| 4 | Toilet - Ladies | 1 | | | | | | | | | | | | | | | | | | | | |
| 5 | Toilet - Gents | 1 | | | | | | | | | | | | | | | | | | | | |
| | FIRST FLOOR | | | | | | | | | | | | | | | | | | | | | |
| 6 | Stair | 1 | | | | | | | | | | | | | | | | | | | | |
| 7 | Room | 1 | | | | | | | | | | | | | | | | | | | | |
| 8 | 705. Boys common room | 2 | | | | | | 2 | | | | | | | | | | | | | | |
| 9 | 706. Electronics circuits lab | | | 9 | | 8 | | | | | | | | | | | | | | | | |

• Canteen Building

| SL. NO | APPLIANCE | T12 (52W) | | T12x2 (104W) | | CFL (14W) | | LED PANEL (15W) | | LED TUBE (18W) | | EXHAUST FAN (60W) | | WALL FAN (50W) | | CEILING FAN (60W) | | COMPUTER (120W) | | PRINTER | | NON STAR AC | | AC | | MIXER GRINDER (500W) | | WATER DISPENSER (50W) | | FREEZER 136W | | BOTTLE COOLER (200W) | |
|--------|--|-----------|------|--------------|------|-----------|------|-----------------|------|----------------|------|-------------------|------|----------------|------|-------------------|------|-----------------|------|---------|------|-------------|------|------|------|----------------------|------|-----------------------|------|--------------|------|----------------------|--|
| | | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | | |
| | Name of Building/Room/Place /Area/Location | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | CANTEEN BUILDING | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | GROUND FLOOR | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Canteen | | | | | | | | | 1 | | | | | 7 | | | | | | | | | | | | | | | 1 | 1 | | |
| 2 | Dining hall | | | | | | | | | 2 | 1 | | | 2 | | | | | | | | | | | | | | 1 | | | | | |
| 3 | Kitchen | | 2 | | | | | | | | 1 | | | | | | | | | | | | | | | | 1 | | | | | | |
| 4 | Entrance | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| | FIRST FLOOR | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 5 | Stair | 1 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |



(Handwritten signature in green ink)

Detailed Energy Audit – Sree Chitra Thirunal Engineering College, Thiruvananthapuram

| SL. NO | APPLIANCE | T12 (52W) | T12x2 (104W) | CFL (14W) | LED PANEL (15W) | LED TUBE (18W) | EXHAUST FAN (60W) | WALL FAN (50W) | CEILING FAN (60W) | COMPUTER (120W) | PRINTER | NON STAR AC | AC | | | MIXER GRINDER (500W) | WATER DISPENSER (50W) | FREEZER 136W | BOTTLE COOLER (200W) | |
|---------------------|---------------------------------------|-----------|--------------|-----------|-----------------|----------------|-------------------|----------------|-------------------|-----------------|---------|-------------|------|--------|-----|----------------------|-----------------------|--------------|----------------------|--|
| | | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | ton | nos. | rating | ton | nos. | nos. | nos. | nos. | |
| 6 | 419. Central computing facility (CCF) | | 1 2 | | 2 | | | | | 5 2 | | | | 3 | 2 | 3 | | | | |
| 7 | Server room | | | | | | | | | | | | | 3 | 2 | 2 | | | | |
| 8 | 417. Advanced system lab | | 1 0 | 3 | | | | | | 4 0 | 1 | | | 3 | 2 | 3 | | | | |
| 9 | 420. Programming lab | | 6 | | | | | 2 | | 2 1 | | | | 3 | 2 | 1 | | | | |
| 10 | Room 2 | | 6 | | | | | 2 | | 1 6 | | | | 3 | 2 | 1 | | | | |
| 11 | 415. Database lab | | 6 | | | | | 3 | | 3 5 | | | | 3 | 2 | 1 | | | | |
| 12 | Room | | | | | | | | | 1 | 1 | 1 5 | | | | | | | | |
| 13 | 418. Project lab | 2 | 2 | | | | | | 4 | 2 0 | | | | 3 | 2 | 1 | | | | |
| 14 | Staff Room | 2 | | | | | | | 1 | | | | | | | | | | | |
| 15 | Staff Room | 1 | | | | | | 1 | | | | | | | | | | | | |
| 16 | Battery Room | | | 1 | | | | | | | | | | | | | | | | |
| 17 | Passage | 1 | | | | | | | | | | | | | | | | | | |
| 18 | 613. Mechatronics lab | 4 | | | | | | 1 | 3 | 2 1 | | | | 5 | 2 | 2 | | | | |
| SECOND FLOOR | | | | | | | | | | | | | | | | | | | | |
| 19 | 401. Staff room - applied science | | | | | | | | 2 | | | | | | | | | | | |
| 20 | 402. Department library | 2 | | | | | | | 1 | | | | | | | | | | | |
| 21 | Seminar hall | | | | | | | | | | | | | 3 | 2 | 2 | | | | |
| 22 | 402. Lecture hall | 4 | | | | | | | 4 | | | | | | | | | | | |
| 23 | Research scholars | 1 | | | | | | | 1 | | | | | | | | | | | |
| 23 | Passage | 4 | | | | | | | | | | | | | | | | | | |
| 24 | Room no 404 | | | | | 4 | | 2 | 1 | | | | | | | | | | | |
| 25 | 403. Lecture hall | 6 | | | | | | | 6 | | | | | | | | | | | |
| 26 | 407A. Lecture hall | 3 | | | | | | | 3 | | | | | | | | | | | |
| 27 | 407B. Lecture hall | 3 | | | | | | | 3 | | | | | | | | | | | |
| 28 | Room no 4.6 | | | | | 8 | | | 8 | | | | | | | | | | | |
| 29 | 411. Engg. Physics lab | | | | | 6 | | | 4 | | | | | | | | | | | |
| 30 | Toilet | 2 | | | | | | | | | | | | | | | | | | |



(Handwritten signature in green ink)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 18

• Post Office Building

| SL.NO | APPLIANCE | T12 (52W) | | T8 (36W) | | LED BULB (9W) | | LED TUBE (18W) | | WALL FAN (50W) | | CEILING FAN (60W) | | COMPUTER (120W) | | PRINTER | | PROJECTOR (500W) | | NON STAR AC | | STAR AC | | |
|-------|-----------------------------|-----------|------|----------|------|---------------|------|----------------|------|----------------|------|-------------------|------|-----------------|------|---------|------|------------------|------|-------------|-----|---------|-----|------|
| | | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | nos. | ton | rating | ton | nos. |
| | POST OFFICE BUILDING | | | | | | | | | | | | | | | | | | | | | | | |
| | GROUND FLOOR | | | | | | | | | | | | | | | | | | | | | | | |
| 1 | Post Office | 6 | | | | | | | | | | 5 | 3 | 2 | | | | | | | | | | |
| 2 | Security Room | 1 | | | | | | | | | | 1 | | | | | | | | | | | | |
| 3 | Ladies common room | | | | | 2 | | | | | | 3 | | | | | | | | | | | | |
| 4 | Toilet | | | 1 | | | | | | | | | | | | | | | | | | | | |
| 5 | Outdoor | | | | 1 | | | | | | | | | | | | | | | | | | | |
| 6 | Medical Room | | | | | 2 | 1 | 1 | | | | | | | | | | | | | | | | |
| 7 | Toilet | | | 1 | | | | | | | | | | | | | | | | | | | | |
| 8 | Outdoor | | | | 1 | | | | | | | | | | | | | | | | | | | |
| | FIRST FLOOR | | | | | | | | | | | | | | | | | | | | | | | |
| 9 | Lab | | | | | 5 | | 3 | 14 | | | 1 | | | | | | | | 3 | | | 2 | |
| 10 | Lecture hall | 4 | | | | | | | | 2 | | | | | | | | | | | | | | |
| 11 | Toilet | | | 1 | | | | | | | | | | | | | | | | | | | | |
| 12 | Lab | | | | 1 | | | | | 5 | | | | | | | | | 1.5 | 1 | | | | |
| 13 | Entrance | 2 | | | | | | | | | | | | | | | | | | | | | | |
| | OUTDOOR | | | | | | | | | | | | | | | | | | | | | | | |
| 14 | Security cabin | | | | | | | | | 1 | | | | | | | | | | | | | | |
| 15 | Substation Room | 1 | 3 | | | | | | | | | | | | | | | | | | | | | |



(Handwritten signature in green ink)


• CGPU Building

| SL.NO | APPLIANCE | T12x2 (104W) | | LED PANEL – ROUND (15W) | | CFL (14W) | LED BULB (9W) | PEDESTAL FAN (55W) | WALL FAN (50W) | COMPUTER (120W) | PRINTER | AC 1.5T | | AC NON STAR | | WATER DISPENSER (50W) | |
|-------|---|--------------|------|-------------------------|------|-----------|---------------|--------------------|----------------|-----------------|---------|---------|------|-------------|-----|-----------------------|------|
| | | nos. | nos. | nos. | nos. | | | | | | | nos. | nos. | rating | ton | | nos. |
| | Name of Building/Room/Place/Area/Location | | | | | | | | | | | | | | | | |
| | CAREER GUIDANCE AND PLACEMENT UNIT OFFICE | | | | | | | | | | | | | | | | |
| 1 | Entrance - outdoor | 7 | | | | | | | | | | | | | | | |
| 2 | Entrance | | 7 | | | | 1 | | 1 | 1 | 5 | 1.5 | 1 | | | | 1 |
| 3 | Room 1 | | | | | | | | 1 | | | | | | | | |
| 4 | Toilet - Gents | | | 1 | 1 | | | | | | | | | | | | |
| 5 | Toilet - Ladies | | | | 1 | | | | | | | | | | | | |
| 6 | Office EDC SCTCE | | 1 | | | | | 1 | | | | | | | | | |
| 7 | Counselling room 1 | | 1 | | | | | | | | | 1.5 | 1 | | | | |
| 8 | Counselling room 2 | | 1 | | | | | | | | | | | | | | |
| 9 | Counselling room 3 | | 1 | | | | | | | | | 1.5 | 1 | | | | |
| 10 | Counselling room 4 | | 1 | | | | | | | | | | | | | | |
| 11 | Counselling room 5 | | 1 | | | | | | | | | | | | | | |
| 12 | Office | | 2 | | | | | 1 | 1 | | | | | 1.5 | 1 | | |



(Handwritten signature in green ink)

PRINCIPAL
Sree Chitra Thirunal
College of Engineering
Trivandrum - 78



ENERGY MANAGEMENT CENTRE - KERALA



Save Energy Save our Planet



Energy Management Centre - Kerala

Department of Energy Management of Kerala
Sree Chitra Thirunai College of Engineering
Thiruvananthapuram 695017
Email: emck@keralaenergy.gov.in Web: www.keralaenergy.gov.in



PRINCIPAL
Sree Chitra Thirunai
College of Engineering
Trivandrum - 18